



To: All Plan Holders of Record

From: CT Consultants, Inc.  
For the Owner

**Re: Addendum No. 1  
Wickliffe Park-N-Ride Lot  
Laketran**

Date: April 21, 2020

This Addendum forms a part of the contract documents and modifies the original bidding documents dated April 2020 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

### **BID OPENING DATE**

The bid opening date shall be changed from April 24, 2020 to May 8, 2020. The time and place of opening shall remain the same.

### **BID FORMS**

The following changes will be made to the Bid Sheet in a subsequent Addendum:

Contract A Ref. No. 35 and Combined Contracts A&B Ref. No. 50 will be changed to 2 Each (Connection to Existing Pipe).

Contract A - Base Ref. No. 24 & Contract A - Alternate Ref. No. 3 as well as Combined Contracts A & B --Ref. No. 39 & Combined Contracts A & B - Alternate Ref. No. 3 will be changed to 632 FT (4' Fence).

### **PLANS**

1. Drawing S-04: **REPLACE** notes 13 & 14 with the following:
  13. USE SIMPSON STRONG-TIE EPB66 POST BASE AT THE BOTTOM OF 6X6 & 8X6 POSTS UNO. USE SIMPSON STRONG-TIE PBS66 POST BASE AT THE WEST CORNER 8X6 POST ONLY.
  14. USE MIN (2) SIMPSON STRONG-TIE LCE4 CONNECTORS BETWEEN THE HEADERS/LVLS AND TOP OF EACH POST. USE SIMPSON H2 OR H2.5 AT EACH ROOF JOIST.

Addendum No. 1  
Date: April 21, 2020  
Page 2

2. Drawing S-05: **REPLACE** Drawing S-05, sheet 30 of 49.
3. Drawing S-06: **REPLACE** the “S-05” in all 12 detail bubbles with “S-06”.

PJF:br

Enclosure

H:\2019\190065\SPEC\Addendum\Addendum 01.Doc