



To: All Plan Holders of Record

From: CT Consultants, Inc.
For the Owner

**Re: Addendum No. 1
Water Storage Tank Replacement
Village of Dresden**

Date: September 3, 2020

This Addendum forms a part of the contract documents and modifies the original bidding documents dated January 2020 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

SPECIFICATIONS

SECTION 13205 – GLASS LINED BOLTED STEEL GROUND STORAGE TANK

- a. Paragraph 2.01.A.18., PROJECT REQUIREMENTS, Overflow – REVISE the minimum size of the overflow pipe from “8-inch” to “6-inch”.

H:\2019\19035301\SPEC\Addenda\2020-09-03 Addendum 1.Docx