



To: All Plan Holders of Record

From: CT Consultants, Inc.  
For the Owner

**Re: Addendum No. 2  
Administration Building Roof Replacement  
Liberty Township**

Date: August 18, 2020

This Addendum forms a part of the contract documents and modifies the original bidding documents dated August 2020 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

### **QUESTIONS & CLARIFICATIONS**

1. **Question:** Drawing details on sheet A-02 indicate both R-20 and R-25 rigid insulation. Please verify which insulation is to be used.

*Answer: The current energy code indicates that a continuous insulation value of R-25 is to be utilized. The R-25 is a minimum. Tapered insulation is required at 1/4 inch per foot per building code requirements.*

2. **Clarification:** All bids received are to be based on the materials specified in the bidding documents provided. Material or roofing system substitutions will not be considered till after the award of the contract.

ADT/CHD:mep

H:\2019\190391\SPEC\Addenda\Addendum 02\Addendum 02.Doc