

To: All Plan Holders of Record

From: CT Consultants, Inc.
Del-Co Water Company

Re: *Addendum No. 2*
Village of Waldo Water Main Improvements
Del-Co Water Company, Inc.

Date: April 11, 2022

This Addendum forms a part of the contract documents and modifies the original bidding documents and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

BID FORMS

Replace Bid Forms, **Pages BF.8 to BF.9**, with the enclosed Bid Forms, *Pages BF.8A to BF.9A*.

BD 9 Prices to Include, Revise the following:

- Add the following to bid items 2 through 8 – Waterline and Water Service.

“All pavement repair caused by water service lines being installed shall be included in the pay items 7 and 8 water services to building. Water service by either boring or open-cut methods will be paid under these same bid items with no differentiation. Payment for grading and seeding work completed is covered separately under that pay item. “

- Delete original bid items 12 and 13.
- Add bid item #29 – Well Abandonment

“Item 29 – Well Abandonment. This item shall include sealing and abandoning customer wells at their request. Scope of work is detailed in the Customer Service Connections note on sheet 2 of the plans.

Payment will be made at the unit price bid for each customer well sealed.”

PLANS

On **Plan Sheet 2**, under the Waterline Construction note, revise 2.4 to read:

“8-inch to 12-inch water line pipe: Minimum Class 200 SDR 21 PVC.”

Addendum No. 2

Date: 4/11/22

Page 2

On **Plan Sheet 7**, **Replace** title “RAILROAD AND ROAD CROSSING DETAIL” with “RAILROAD CROSSING DETAIL”. Also **Change** the detail note to read “*PROVIDE CASING PIPE FOR ALL RAILROAD CROSSINGS UNLESS OTHERWISE APPROVED...*”.

On **Plan Sheet 9** under the “PAVEMENT REPAIRS” notes, **Add** the following note: “3. *CONCRETE BASE WILL NOT BE ALLOWED FOR TRENCH REPAIR.*”

PREVAILING WAGES

Section 9, Prevailing Wage Rates - **REPLACE** the Wage Rate Schedule with the following:

Heavy and Highway – Decision No. OH20220001, Modification No. 6, dated 04/08/2022

QB:mep

Enclosures

H:\2019\191114\SPEC\Addenda\Addendum 02\Addendum 02.Doc