

To: All Plan Holders of Record

From: CT Consultants, Inc.
For the Owner

**Re: Addendum No. 1
WWTP Dilution Waterline Improvements
Village of Hartville**

Date: June 03, 2022

This Addendum forms a part of the contract documents and modifies the original bidding documents dated May 2022 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

PLANS

Plan Sheet 4 of 8 – **ADD** the following to Non-Potable Waterline Note 1:

“PIPE SHALL COMPLY WITH THE IPS SIZING SYSTEM, FOR THE SIZES INDICATED ON THE DRAWINGS.”

Plan Sheet 4 of 8 – **ADD** the following to the Non-Potable Waterline Notes:

“10. AIR RELEASE VALVE SHALL CONSIST OF A 1-INCH INLET & OUTLET, 150 PSI OPERATING PRESSURE, CAST IRON BODY & COVER, STAINLESS STEEL FLOAT, INTERNAL LINKAGE & EXTERNAL FASTENERS, AND BUNA-N REPLACEABLE SEAT. GA INDUSTRIES, FIGURE 945-T, OR APPROVED EQUAL.

11. PRECAST CONCRETE MANHOLE UNITS SHALL BE MANUFACTURED IN ACCORDANCE WITH ASTM C-478. JOINTS SHALL BE GASKETED AND COMPLY WITH ASTM C-443. CONNECTORS BETWEEN MANHOLE AND PIPE SHALL COMPLY WITH ASTM C-923.”

QUESTIONS AND ANSWERS

Q1 – Is installation of the proposed Dilution Waterline by Horizontal Directional Drilling an acceptable alternative to Open Cut/Trenching?

A1 – Yes, Horizontal Direction Drilling is an acceptable installation method for this project.

SA/EF:mep

Enclosures