



To: All Plan Holders of Record

From: CT Consultants, Inc.
For the Owner

Re: *Addendum No. 1*
Water Treatment Plant – REBID Filter Media Replacement
Village of Brewster

Date: October 22, 2021

This Addendum forms a part of the contract documents and modifies the original bidding documents dated October 2021 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

SPECIFICATIONS

SPECIFICATION SECTION 466113 - FILTER MEDIA

- **Change** Part 2.1 I. as follows:

1. Media shall be supported by a 13-inch graded gravel support bed. 3/4 - 1 1/2 gravel is to be put into tank first. Each successive layer shall be of smaller size gravel until the final layer of 1/16 - 1/8 gravel is placed.

APPENDIX

FILTER #4 TANK RELOCATION STRUCTURAL NOTES

- **Change** Note 1.f. to read “Tank contents (to be removed by Contractor prior to relocation, except as noted): ...”
- **Replace** Note 4 as follows “Filter tank shall be completely drained and all contents removed by Contractor (with the exception of the concrete fill) prior to lifting & moving.”
- **Change** Note 24 to read “...shall be bulk-headed and filled with concrete to floor level by the Contractor, in accordance with the following: ...”
- **Change** Note 25 to read “Following adequate cure and strength development of the aforementioned concrete fill, Contractor may proceed...”

GC:mep

Enclosures

H:\2020\200559\SPEC\Rebid\Addenda\Addendum 01\Addendum 01_Rebid.Doc