

To: All Plan Holders of Record

From: CT Consultants, Inc.  
For the Owner

**Re: *Addendum No. 1***  
***Madison Co. - PY 2020 CDBG Program - South Solon Neighborhood Revitalization***  
***Grant, Contract B: Wastewater & Water Treatment Plant Improvement***  
***Madison Co. Commissioners - REBID***

Date: May 24, 2023

This Addendum forms a part of the contract documents and modifies the original bidding documents dated May 2023 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

## **SPECIFICATIONS**

### **1. SECTION 462100.01 – FINE SCREEN EQUIPMENT**

**DELETE** Paragraph 2.7.H. in its entirety.

The unit as proposed need not include an Operator Interface Terminal. The HOA components and controls required by the specification provide control interface for the unit.

BA/BR:mjl

H:\2021\210092\SPEC\Contract B - WWTP & WTP\Rebid\Addenda\Addendum 01.Docx