

---

***SECTION 5***  
***SPECIFICATIONS***

---

## SECTION 011000 - SUMMARY OF WORK

### PART 1 - GENERAL

#### 1.1 LOCATION OF THE PROJECT

- A. The projects are located at various locations in the City of Willowick. See the list in this section.

#### 1.2 PROJECT DESCRIPTION

- A. Lateral rehabilitations by cured-in-place pipe (CIPP) lining and lateral replacements from the sanitary and storm mains in the street to the right-of-way at various locations in the City.

#### 1.3 SPECIFICATIONS

- A. In general, these Specifications describe the work to be performed by the various trades, other than work specifically excluded. It shall be the responsibility of Contractors and Subcontractors to perform all work incidentals to their trade, whether or not specific mention is made of each item, unless such incidentals are included under another Item.
- B. It is advised that all Contractors and Subcontractors familiarize themselves with the contents of the complete Specifications, particularly for the trades preceding, following, related or adjacent to their work.

#### 1.4 DRAWING SCHEDULE

- A. The work to be done under this Contract is shown on the following Drawings:

<u>Title</u>	<u>Plans</u>
Lateral Repairs - Detail Drawings	DD.1 to DD.9

#### 1.5 LATERAL REPAIR PROGRAM

- A. Below is a list of 21 locations of laterals which may be increased or decreased at the direction of the City. The approximate upstream and downstream manhole depths for the sanitary and storm sewer near each property is listed for estimating depth of lateral connections in the event replacement is required.

<b>House Number</b>	<b>Address</b>	<b>Riser</b>	<b>Type Test</b>	<b>Replace or CIPP liner</b>	<b>Sanitary Depth Range (ft.)</b>	<b>Storm Depth Range (ft.)</b>
360	BLISSFIELD	Plastic	Residential POS	CIPP	9.5-11.0	7.8-9.2
581	CRESCENT	Clay	Residential POS	CIPP	8.3-8.7	9.5-9.6
614	DICKERSON	Plastic	Residential POS	Replace	10.5-10.6	8.6-8.9
29150	FOREST GROVE	Clay	Residential POS	CIPP	14.5-15.5	4.8-5.3
29315	GREEN	Clay	Residential POS	CIPP	9.9-10.0	8.3-8.6
659	PENDLEY	Clay	Residential POS	CIPP	10.4-10.6	7.2-7.8
698	PENDLEY	Plastic	Residential POS	CIPP	7.9-10.4	4.1-7.2
30316	VINEYARD	Clay	Residential POS	CIPP	8.9-9.7	6.7-7.5
28743	FOREST	Plastic	Residential POS	CIPP	7.4-8.0	5.7-7.8
217	E 284	Clay	Residential POS	CIPP	11.9-13.6	10.8-11.6
226	E 286	Plastic	Residential POS	Replace	8.1-8.4	7.8-9.0
318	E 286	Plastic	Residential POS	Replace	8.1-8.5	7.3-7.9
364	E 308	Clay	Residential POS	CIPP	7.7-8.0	7.0-7.5
385	E 308	Clay	Residential POS	CIPP	7.7-8.0	7.0-7.5
156	E 316	Clay	Residential POS	CIPP	7.9-9.4	8.0-8.1
276	E 317	Clay	Residential POS	CIPP	9.9-12.9	8.3-11.1
296	E 317	Clay	Residential POS	CIPP	9.9-12.9	8.3-11.1
388	E 322	Clay	Residential POS	Replace	10.1-10.3	6.7-6.8
379	E 323	Plastic	Residential POS	CIPP	9.3-9.8	6.5-7.9
279	E 324	Plastic	Residential POS	CIPP	8.2-11.3	6.1-7.1
455	E 328	Plastic	Residential POS	CIPP	7.3-7.9	7.8-9.2

The bid form contains an item for televising lateral connections from the mainline or clean out further described as follows:

The Contractor shall televise all laterals before making designated improvements to the storm or sanitary lateral from main to right-of-way line. The Engineer shall review such videos to confirm that designated improvement is appropriate based observed conditions. Locations designated to be CIPP lined will have the sanitary lateral lined as specified. If lateral designated to be lined is found to be in condition that is unable to be CIPP lined, then the Contractor shall replace lateral(s) in accordance with all specifications and details.

For lateral replacements, the 6-inch sanitary and storm sewer lateral connections to existing mains shall be made as follows:

New lateral connections to the mainline wye may be made by:

- Connecting to the first section of lateral pipe above the mainline wye with tri-band resilient coupler; or
- Connection to the mainline wye bell with O-ring pipe adaptor; or by diamond bit core drilling the appropriate size hole for the size and type of lateral pipe and type and brand of resilient saddle and utilizing a resilient saddle installed per the manufacturer's directions and plugging and sealing the existing tee or wye with hydraulic cement. The saddle shall be Kor-N-Tee, Twist Tee, or T-Flex as shown on the Detailed Drawings or approved equal.

Additional payment will be made if the existing wye is found to be damaged or it is otherwise necessary to install a new main tee, nipples and tri-band resilient couplers in place of the existing tee.

The bid form contains an item for replacement of the test tee/clean outs at the R/W. In this case, the existing metal top castings shall be salvaged and re-used.

For lateral rehabilitation by CIPP lining, the work shall include lining the lateral(s) in accordance with specifications and also installing a mainline connection liner using T-liner, or approved equal for a watertight seal at the mainline connection.

END OF SECTION 011000

## SECTION 011419 – USE OF SITE

### PART 1 - GENERAL

#### 1.1 GENERAL

- A. The Contractor will be allowed the use of as much of the site designated for the improvements as is necessary for their operation.

#### 1.2 USE OF STREETS

- A. During the progress of the work, the Contractor shall make ample provisions for both vehicle and pedestrian traffic on any public street and shall indemnify and save harmless the Owner from any expense whatsoever due to their operations over said streets. The Contractor shall also provide free access to all the fire hydrants, water, and gas valves located along the line of their work. Gutters and waterways must be kept open or other provisions made for the removal of storm water. Street intersections may be blocked only one-half at a time, and the Contractor shall lay and maintain temporary driveways, bridges and crossings, such as in the opinion of the Engineer are necessary to reasonably accommodate the public.
- B. In the event of the Contractor's failure to comply with these provisions, the Owner may cause the same to be done, and may deduct the cost of such work from any monies due the Contractor under this Agreement, but the performance of such work by the Owner at its instance shall serve in no way to release the Contractor from their general or particular liability for the safety of the public or the work.
- C. The Contractor shall repair at no cost to the Owner, all existing roads, parking areas, grassed areas that are damaged due to the execution of their work. The Contractor shall remove daily all mud, soil and debris that may be tracked onto existing streets, drives, or walks by their equipment or that of subcontractors or suppliers.

#### 1.3 CLOSING STREETS TO TRAFFIC

The Contractor may with the approval of the Engineer, close streets, or parts of streets, to vehicular traffic. The streets are to remain closed as long as the construction work or the condition of the finished work requires or as determined by the Engineer. The Engineer shall be the judge of how many streets or parts of streets it is necessary for the Contractor to close at any time, and may refuse to permit the closing of additional streets to traffic until the majority of the work on the closed streets is completed and they are opened to traffic.

#### 1.4 RIGHTS-OF-WAY

- A. Whenever it is required to perform work within the limits of public or private property or in rights-of-way, such work shall be done in conformity with all agreements between the Owner and the owners of such. Care shall be taken to avoid injury to the premises entered, which premises shall be left in a neat and orderly condition by the removal of rubbish and the grading of surplus materials, and the restoration of said public or private property to the same general conditions as pertained at the time of entry for work to be performed under this contract.
- B. The Contractor shall not (except after consent from the proper parties) enter or occupy with men, tools or equipment, any land outside the rights-of-way or property of the Owner.
- C. When the Contractor performs construction within 10 ft. of a right-of-way or easement line, he shall place tall stakes properly identified at points of change in width or direction of the right-of-way or easement line and at points along the line so that at least two stakes can be seen distinctly from any point on the line.

#### 1.5 EASEMENTS

- A. Where the work is to be constructed upon easements, such easements will be secured by the Owner without cost to the Contractor. The Contractor shall not enter upon or occupy any private property outside of the limits of the easements furnished.
- B. Care shall be taken to avoid injury to the premises entered, which premises shall be left in a neat and orderly condition by the removal of rubbish and the grading of surplus materials, and the restoration of said public or private property to the same general conditions as pertained at the time of entry for work to be performed under this contract.

#### 1.6 PROTECTING EXISTING BUILDINGS, STRUCTURES AND ROADWAYS

- A. The Contractor shall, at their own expense, shore up and protect any buildings, roadways, utilities or other public or private structures which may be encountered or endangered in the prosecution of the work, and that may not be otherwise provided for, and he shall repair and make good any damages caused to any such property by reason of their operations. All existing fences removed due to the prosecution of the work shall be replaced by the Contractor. No extra payment will be made for said work or material, but the cost of this work must be included in the price stipulated for the work to be done under this contract.

#### 1.7 SITE FACILITIES

- A. The Contractor shall furnish and place sufficient quantities of portable toilet facilities at locations convenient for use by the Contractor's personnel, Subcontractors, the Engineer, and the Owner.

1.8 RESTORATION

- A. The contractor shall restore all areas per the plans and specifications and if not specified, at least to the condition existing prior to the start of work.

END OF SECTION 011419

## SECTION 011423 - ADDITIONAL WORK, OVERTIME

### PART 1 - GENERAL

#### 1.1 NIGHT, SUNDAY AND HOLIDAY WORK

- A. No work will be permitted at night, Sunday or legal holidays except as noted on the plans or in the case of emergency and then only upon written authorization of the Engineer. Where no emergency exists, but the Contractor feels it advantageous to work at night, Sunday or legal holidays, the Contractor shall notify the Engineer at least two (2) days in advance, requesting written permission. Any work performed during the absence of the Engineer will be done at the Contractor's risk and responsibility and may be subject to rejection upon later inspection.

END OF SECTION 011423



## SECTION 012513 – PRODUCT SUBSTITUTION PROCEDURES

### PART 1 - GENERAL

#### 1.1 MATERIALS AND EQUIPMENT

- A. In the specifications and on the Engineer's drawings, are specified and shown certain pieces of equipment and materials deemed most suitable for the service anticipated. This is not done to eliminate other equipment and materials equally as good and efficient. The Contractor shall prepare their bid on the particular materials and equipment specified. Following the award of the contract, should the Contractor desire to use other equipment and materials, he shall submit to the Owner a written request for such change and state the advantage to the Owner and the savings or additional cost involved by the proposed substitution. The determination as to whether or not such change will be permitted rests with the Owner and the Engineer.
- B. Each major item of equipment shall be inspected by a manufacturer's representative during installation and upon completion of the work. The Contractor shall supply the Engineer with a certificate of such inspection.

END OF SECTION 012513

## SECTION 013119 - PROJECT MEETINGS

### PART 1 - GENERAL

#### 1.1 PRECONSTRUCTION MEETING

- A. Prior to the Contractor beginning any work on the project, the Owner will schedule and hold a preconstruction meeting to discuss all aspects of the contract work.
- B. The Contractor shall be present and be prepared to comment in detail on all aspects of their work.
- C. The Contractor shall bring to the preconstruction meeting a proposed construction progress schedule, erosion control plan, quality control program, concrete mix designs, asphalt mix designs (JMF), etc. Approval of each by the Engineer is required prior to the start of any work.
- D. Included in the construction progress schedule shall be an implementation sequence of the proposed erosion control efforts required by the contract.

#### 1.2 PROGRESS MEETINGS

- A. Monthly progress meetings will be held at a location to be determined by the Owner on a regularly scheduled day mutually convenient to the Owner, Contractor, and Engineer.
- B. The Contractor shall provide an updated construction progress schedule and be prepared to comment in detail on all aspects of his work.

END OF SECTION 013119

## SECTION 013216 – CONSTRUCTION PROGRESS SCHEDULE

### PART 1 - GENERAL

#### 1.1 PROGRESS SCHEDULE

- A. Immediately after signing the Contract, the General Construction Contractor shall prepare a graphic progress schedule, indicating the work to be executed during each month and the rate of expected progress to secure completion on the agreed-upon completion date. The progress schedule shall be approved by the Engineer and Owner prior to starting work on the site. Copies of such graphic progress charts, upon which has been indicated the actual progress, shall be furnished to the Engineer with each requisition for payment.
- B. Should the rate of progress fall materially behind the scheduled rate of progress, and unless the delay is authorized by the Engineer, each offending Contractor shall furnish additional labor, work overtime, or take other necessary means required for completion of the work on the scheduled date. No additional compensation beyond the set Contract price shall be paid for action taken or overtime expense incurred in maintaining scheduled progress.

END OF SECTION 013216

## SECTION 013223 – SURVEY AND LAYOUT DATA

### PART 1 - GENERAL

#### 1.1 STAKING

- A. The Contractor shall hire a surveyor licensed in the state the work is to be installed to provide all reference points not already established and staking. The Contractor shall protect and preserve the established staking and reference points as long as required for installation of the work and field verifications by any party. The Contractor's surveyor shall replace and accurately relocate all staking and reference points so lost, destroyed or moved.

#### 1.2 LAYOUT OF WORK

- A. The Contractor shall lay out their work and be responsible for correct locations, elevations and dimensions of all work executed by him under this Contract. The Contractor must exercise proper precautions to verify the figures shown on the Drawings before laying out the work and will be held responsible for any error resulting from their failure to exercise such precaution. The Contractor shall insure the new construction aligns with any existing work.

END OF SECTION 013223

## SECTION 013236 – VIDEO MONITORING AND DOCUMENTATION

### PART 1 - GENERAL

#### 1.1 SCOPE

- A. Provide all labor, materials, equipment, and services, and perform all operations necessary to furnish to the Owner a complete color audio-video mp4 record of the surface features within the proposed construction zone of influence. This record shall include, but not be limited to, all USB storage drives with audio-video files, video logs, and indexes. The purpose of this coverage shall be to accurately document the pre-construction condition of these surface features.

#### 1.2 QUALIFICATIONS

- A. The video documentation shall be done by a responsible commercial firm known to be skilled and regularly engaged in the business of pre-construction color audio-video documentation. The firm shall furnish such information as the Owner deems necessary to determine the ability of that firm to perform the work in accordance with the Contract specifications.

#### 1.3 PRODUCTS

- A. The color audio-video recording delivered to the Owner shall be on a high quality mp4 format on a USB storage drive or by providing access to a file hosting website where the Owner and Engineer can access and download the mp4 files.

END OF SECTION 013236

# SECTION 013319.01 - FIELD TEST REPORTING - AGGREGATE, SOILS, CONCRETE AND ASPHALT

## PART 1 - GENERAL

### 1.1 SUMMARY

- A. The Contractor shall be responsible for the quality of all materials incorporated into the project work and shall be responsible for all costs for testing and certification of same.
- B. The Contractor shall provide the engineer with a Quality Control Plan in which their testing methods/procedures are defined. Said Plan shall meet with the approval of the Engineer and include identification of laboratories, types of testing, and the tentative amount and scheduling of each.

All certification of tests and/or gradations for material to be utilized in the work and all quality control testing shall be performed by an independent laboratory (not affiliated with, owned by, or managed by the Contractor). The laboratory shall be accredited by the AASHTO Materials Reference Laboratory for the type of testing performed.

- C. The Owner may perform field Quality Assurance testing; however, such testing shall not relieve the Contractor from the responsibility of Quality Control testing or from supplying certificates from manufacturers or suppliers to demonstrate compliance with the specifications. It is intended that the testing by the Contractor and the Owner be complimentary toward a quality project; however, the Contractor may not assume the Owner will test or that any tests will be done in lieu of the Contractor's own Quality Control testing. In the same sense, the Contractor may not rely on Owner Quality Assurance testing as a basis of acceptance or approval of their work nor may any Owner-performed testing be reflected in their submitted plan.

### 1.2 TEST CRITERIA

- A. The following tests at a minimum shall be included with the Contractor's Quality Control Plan in accordance with the specifications:
  - 1. Aggregates
    - a. For each material and/or different source, the laboratory shall perform soundness, gradation, and other tests for all parameters specified. Aggregates incorporated into concrete or asphalt mixes shall also be tested for moisture content daily.
  - 2. Compaction Tests
    - a. Compaction tests or field density tests shall be taken on all embankment, trench backfill, subgrade, and subbase materials.

- b. Minimum testing shall be as follows:
    - Embankment testing shall be at least one (1) test/5,000 SF of each lift; Trench backfill testing shall be at least one (1) test/50 LF of each lift; Subgrade and/or subbase testing shall be at least one (1) test/200 LF of pavement or 5,00 SF of slabs; subject to greater frequency due to soil conditions or Engineer's direction.
  - c. Proctors or relative density tests shall be performed as often as necessary for the differing soils or granular materials utilized. Proctors shall be run with a minimum of 5 points. Test reports shall show the wet (bulk) weight, dry weight, wet (bulk) density, dry density, moisture content weight and moisture content percentage. Both the dry curve and the wet curve shall be plotted.
3. Concrete Mix Design
- a. For each type of concrete, the laboratory shall perform the necessary mix design providing all test data as required by the specifications.
4. Concrete Field and Laboratory Tests
- a. The laboratory shall cast concrete cylinders and test beams:
    - 1. One set of four cylinders per 50 CY with a minimum of two sets per day. The cylinders shall be broken: one at 7 days, two at 28 days, one at 56 days, unless otherwise directed by the Engineer.
    - 2. One beam per 50 CY with a minimum of two beams per day.
  - b. Temperature and unit weight shall be run on fresh concrete at intervals sufficient for the type of structure being placed and a minimum of once per day. Bulk weight, bucket weight, (tare), net weight, bucket factor (bucket volume) and unit weight shall be recorded on the fresh concrete report. Slump and air content tests shall be taken a minimum of one test per 20 CY and at least once per day.
  - c. All field and laboratory testing shall be performed by technicians certified by the American Concrete Institute (ACI) for the type of testing performed.
  - d. Initial cure of all cylinders shall be in a temperature controlled cure box or temperature controlled water tank with a hi-low thermometer. Hi-low temperature readings shall be recorded on the fresh concrete report.
5. Asphalt Mix Design
- a. For each type of asphalt mix, submit job mix formula (JMF) prepared by an ODOT pre-qualified laboratory from tests performed on the aggregates proposed for use.
  - b. Sample and test for gradation and bitumen content per ODOT 441.

### 1.3 LABORATORY REPORTS

- A. Reports of laboratory and field tests will be distributed to the Engineer, Owner, and Suppliers within 24 hours of completion.

END OF SECTION 013319.01



## SECTION 013323 - SHOP DRAWINGS, PRODUCT DATA AND SAMPLES

### PART 1 - GENERAL

#### 1.1 GENERAL

- A. The Contractor shall submit detailed drawings, acceptable catalog data, specifications and material certifications for all equipment and materials specified or required for the proper completion of the work.
- B. The intent of these items is to demonstrate compliance with the design concept of the work and to provide the detailed information necessary for the fabrication, assembly and installation of the work specified. It is not intended that every detail of all parts of manufactured equipment be submitted, however sufficient detail will be required to ascertain compliance with the specifications and establish the quality of the equipment proposed.

Shop Drawings shall be sufficiently clear and complete to enable the Engineer/Architect and Owner to determine that items proposed to be furnished conform to the specifications and that items delivered to the site are actually those that have been reviewed.

- C. It is emphasized that the Engineer/Architect's review of Contractor's submitted data is for general conformance to the contract drawings and specifications, but subject to the detailed requirements of drawings and specifications. Although the Engineer/Architect may review submitted data in detail, such review is an effort to discover errors and omissions in Contractor's drawings. The Engineer/Architect's review shall in no way relieve the Contractor of their obligation to properly coordinate the work and to Engineer/Architect the details of the work in such manner that the purposes and intent of the contract will be achieved. Such review by the Engineer/Architect shall not be construed as placing on him or on the Owner any responsibility for the accuracy and for proper fit, functioning or performance of any phase of the work included in the contract.
- D. Shop Drawings shall be submitted in proper sequence and with due regard to the time required for checking, transmittal and review so as to cause no delay in the work. The Contractor's failure to transmit appropriate submittals to the Engineer/Architect sufficiently in advance of the work shall not be grounds for time extension.
- E. The Contractor shall submit Shop Drawings for all fabricated work and for all manufactured items required to be furnished in the Contract in accordance with the General Provisions and as specified herein. Shop Drawings shall be submitted in sufficient time to allow at least twenty-one (21) calendar days after receipt of the Shop Drawings from the Contractor for checking and processing by the Engineer/Architect.
- F. It is the responsibility of each Prime Contractor to furnish to all other Prime Contractors and especially the General Construction Contractor reviewed Shop Drawings for guidance in interfacing the various trades; i.e., sleeves, inserts, anchor bolts, terminations, and space requirements.

- G. No work shall be performed requiring Shop Drawings until same have been reviewed by Engineer/Architect.
- H. Accepted and reviewed Shop Drawings shall not be construed as approval of changes from Contract plan and specification requirements.
- I. The Engineer/Architect will review the first and second Shop Drawing item submittals at no cost to the Contractor. Review of the third submittal and any subsequent submittal will be at the Contractor's expense. Payment will be deducted from the Contract amount at a rate of 2.8 times direct labor cost plus expenses.

## 1.2 SUBMITTAL PROCEDURE

- A. All required submissions shall be made to the Engineer/Architect by the Prime Contractor(s) only. Any data prepared by subcontractors and suppliers and all correspondence originating with subcontractors, suppliers, etc., shall be submitted through the Contractor.
- B. Contractor shall review and approve all Shop Drawings prior to submission. Contractor's approval shall constitute a representation to Owner and Engineer/Architect that Contractor has either determined and verified all quantities, dimensions, field construction criteria, materials, catalog numbers, and similar data or assumes full responsibility for doing so, and that Contractor has reviewed or coordinated each Shop Drawing or sample with the requirements of the work and the Contract Documents.
- C. Submittal Preparation: Mark each submittal with a permanent label or page for identification. Provide the following information on the label for proper processing and recording of action taken:
  - 1. Location
  - 2. Project Name
  - 3. Contract
  - 4. Name and Address of Engineer/Architect
  - 5. Name and Address of Contractor
  - 6. Name and Address of Subcontractor
  - 7. Name and Address of Supplier
  - 8. Name of Manufacturer
  - 9. Number and Title of appropriate Specification Section
  - 10. Drawing Number and Detail References, as appropriate.
  - 11. Submittal Sequence or Log Reference Number.
    - a. Provide a space on the label for the Contractor's review and approval markings and a space for the Engineer/Architect's "Action Stamp".
- D. Each Shop Drawing, sample and product data submitted by the Contractor shall have affixed to it the following Certification Statement including the Contractor's Company name and signed by the Contractor:

Certification Statement: By this submittal, I hereby represent that I have determined and verified all field measurements, field construction criteria, materials, dimensions, catalog numbers and similar data and I have checked and coordinated each item with other applicable approved shop drawings and all Contract requirements.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company

- E. Shop Drawings shall be submitted in not less than six (6) copies to the Engineer/Architect at the address specified at the Preconstruction Conference. Single mylar or sepia reproducible copies of simple Shop Drawings may be submitted with prior approval of the Engineer/Architect.
- F. At the time of each submission, Contractor shall in writing identify any deviations that the Shop Drawings or samples may have from the requirements of the Contract Documents.
- G. Drawings shall be clean, legible and shall show necessary working dimensions, arrangement, material finish, erection data, and like information needed to define what is to be furnished and to establish its suitability for the intended use. Specifications may be required for equipment or materials to establish any characteristics of performance where such are pertinent. Suitable catalog data sheets showing all options and marked with complete model numbers may, in certain instances, be sufficient to define the articles which it is proposed to furnish.
- H. For product which require submittal of samples, furnish samples so as not to delay fabrication, allowing the Engineer reasonable time for the consideration of the samples submitted. Properly label samples, indicating the material or product represented, its place of origin, the names of the vendor and Contractor and the name of the project for which it is intended. Ship samples prepaid. Accompany samples with pertinent data required to judge the quality and acceptability of the sample, such as certified test records and, where required for proper evaluation, certified chemical analyses.

### 1.3 REVIEW PROCEDURE

- A. Engineer/Architect will review with reasonable promptness all properly submitted Shop Drawings. Such review shall be only for conformance with the design concept of the Project and for compliance with the information given in the plans and specifications and shall not extend to means, methods, sequences, techniques or procedures of construction or to safety precautions or programs incident thereto.
- B. The review of a separate item as such will not constitute the review of the assembly in which the item functions. The Contractor shall submit entire systems as a package.
- C. All Shop Drawings submitted for review shall be stamped with the Engineer/Architect's action and associated comments.

- D. Except for submittals for record, information or similar purposes, where action and return is required or requested, the Engineer/Architect will review each submittal, mark to indicate action taken, and return accordingly. Compliance with specified characteristics is the Contractor's responsibility.

Action Stamp: The Engineer/Architect will stamp each submittal with a uniform, self-explanatory action stamp. The stamp will be appropriately marked, as follows, to indicate the action taken:

1. If Shop Drawings are found to be in general compliance, such review will be indicated by marking the first statement.
  2. If only minor notes in reasonable number are needed, the Engineer/Architect will make same on all copies and mark the second statement. Shop Drawings so marked need not be resubmitted.
  3. If the submitted Shop Drawings are incomplete or inadequate, the Engineer/Architect will mark the third statement, request such additional information as required, and explain the reasons for revision. The Contractor shall be responsible for revisions, and/or providing needed information, without undue delay, until such Shop Drawings are acceptable. Shop Drawings marked with No. 3 shall be completed resubmitted.
  4. If the submitted Shop Drawings are not in compliance with the Contract Documents, the Engineer/Architect will mark the fourth statement. The Contractor will be responsible to submit a new offering conforming to specific products specified herein and/or as directed per review citations.
- E. No submittal requiring a Change Order for either value or substitution or both, will be returned until the Change Order is approved or otherwise directed by the Owner.

## APPLICATION FOR USE OF SUBSTITUTE ITEM

TO: \_\_\_\_\_

PROJECT: \_\_\_\_\_

SPECIFIED ITEM:

Page	Paragraph	Description
A.		The undersigned requests consideration of the following as a substitute item in accordance with Article 6.05 of the General Conditions.
B.		Change in Contract Price (indicate + or -) \$ _____
C.		Attached data includes product description, specifications, drawings, photographs, references, past problems and remedies, and performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified. For consideration of the attached data as SHOP DRAWINGS, submittal shall be in accordance with requirements of Section 013323.
D.		Attached data also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

The undersigned certifies that the following paragraphs, unless modified by attachments are correct:

1. The proposed substitute does not affect dimensions shown on Drawings.
2. The undersigned will pay for changes to the building design, including engineering design, detailing, and construction costs caused by the requested substitution.
3. The proposed substitution will have no adverse affect on other contractors, the construction schedule, or specified warranty requirements. (If proposed substitution affects construction schedule, indicate below using + or -)

\_\_\_\_\_ CONSECUTIVE CALENDAR DAYS

4. Maintenance and service parts will be locally available for the proposed substitution.

The undersigned further states that the function, appearance, and quality of the proposed substitution are equivalent or superior to the specified item, and agrees to reimburse the OWNER for the charges of the ENGINEER for evaluating this proposed substitute item.

E. Signature:

Firm:

Address:

Telephone:

Date:

Attachments:

For use by ENGINEER:

\_\_\_\_\_ Accepted as evidenced by affixed SHOP DRAWING REVIEW stamp.

\_\_\_\_\_ Accepted as evidenced by included CHANGE ORDER.

\_\_\_\_\_ Not accepted as submitted. See Remarks.

\_\_\_\_\_ Acceptance requires completion of submittal as required for SHOP DRAWINGS.

\_\_\_\_\_ Not accepted. Do not resubmit.

By:

Date:

Remarks:

# APPLICATION FOR USE OF "OR-EQUAL" ITEM

TO: \_\_\_\_\_

PROJECT: \_\_\_\_\_

SPECIFIED ITEM:

Page	Paragraph	Description
------	-----------	-------------

A. The undersigned requests consideration of the following as an "or-equal" item in accordance with Article 6.05 of the General Conditions.

B. Change in Contract Price (indicate + or -) \$ \_\_\_\_\_

C. Attached data includes product description, specifications, drawings, photographs, references, past problems and remedies, and performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified. For consideration of the attached data as SHOP DRAWINGS, submittal shall be in accordance with requirements of Section 013323.

D. Signature:

Firm: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Telephone: \_\_\_\_\_

Date: \_\_\_\_\_

Attachments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

For use by ENGINEER:

\_\_\_\_\_ Accepted as evidenced by affixed SHOP DRAWING REVIEW stamp.

\_\_\_\_\_ Accepted as evidenced by included CHANGE ORDER.

\_\_\_\_\_ Not accepted as submitted. See Remarks.

\_\_\_\_\_ Acceptance requires completion of submittal as required for SHOP DRAWINGS.

\_\_\_\_\_ Not accepted. Do not resubmit.

By: \_\_\_\_\_ Date: \_\_\_\_\_

Remarks: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

END OF SECTION 013323



## SECTION 013326 – PRODUCT TESTING AND CERTIFYING

### PART 1 - GENERAL

#### 1.1 QUALITY OF MATERIALS

- A. Where the specifications call for mill or shop tests, the Contractor shall furnish duplicate copies of attested manufacturer's certificates showing details of quality or performance sufficient to demonstrate conformity to contract requirements. Mill, shop or witness tests shall be subject to view by the Engineer's representative, but the Engineer's representation shall not relieve the Contractor from the necessity of furnishing certificates specified. The Engineer shall be notified by the Contractor in writing, sufficiently in advance of the time of making tests, so that proper arrangements may be made. Waiving of witness of tests by the Engineer may be in writing only by the Engineer. All costs for travel, lodging, food and transportation that are necessary for the Engineer's representative and the Owner's representative to attend witness tests shall be included in the Contractor's bid for those item(s) specifically designated as being subject to witness testing.
- B. Unless otherwise specified, all materials, equipment and articles shall be erected, installed, applied, or connected, used, cleaned and conditioned in accordance with the printed instructions and directions of the manufacturer.
- C. The installation shall be so made that its several component parts will function together as a workable system. It shall be complete with all accessories necessary for its operation and shall be left with all equipment properly adjusted and in working order.
- D. The work shall be executed in conformity with the best practice and so as to contribute to efficiency of operation, minimum maintenance, accessibility and sightliness. It shall also be executed so that the installation will conform and accommodate itself to the building structure, its equipment and usage.
- E. Whenever in the contract documents a particular brand, make of material, device or equipment is shown or specified, such brand, make of material, device or equipment is to be regarded merely as a standard and such trade name shall be followed by "or equal".

#### 1.2 QUALITY ASSURANCE

- A. The equipment and materials to be furnished under this Contract shall be the products of well established and reliable firms which have had ample experience for at least five (5) years in the manufacture of equipment or materials similar in design and of equal quality to that specified. If required, the manufacturer shall submit a list of installations of similar equipment which have been in successful operation for at least five (5) years.

1.3 EXPERIENCE CLAUSE REQUIREMENT AND PERFORMANCE BONDS FOR MANUFACTURER

- A. For every piece of equipment furnished under this Contract, the manufacturer will be required to have a minimum of five (5) years of experience in providing this specific type of equipment. In lieu of this experience requirement, the manufacturer will be required to provide performance bond(s) for the faithful performance of the equipment and guarantee payment in a sum of not less than one hundred and fifty percent (150%) of the total equipment price for the completed work for that item. In the absence of verifiable experience, the manufacturer will be required to provide the performance bond(s) for the same number of years that the manufacturer was found lacking in experience from the specified five (5) year period. The performance bond(s) shall be from an approved surety company, to the satisfaction of the Owner's Law Director.
- B. Agents of bonding companies which write bonds for the performance and payment of the contract shall furnish power of attorney bearing the seal of the company, evidencing such agent's authority to execute the particular type of bond to be furnished, and evidencing also the right of the surety company to do business in the State of Ohio. Copy of this proof shall be attached to each copy of the contract.
- C. The bond shall be purchased through a surety company with a local agent upon whom service of process can be made.
- D. In event of failure of surety or co-surety, the manufacturer shall immediately furnish a new bond, as required herein. The manufacturer's bond will not be released until all provisions of the contract have been fulfilled.
- E. The surety used for the bid bond and performance bond shall be listed in the latest U.S. Treasury Circular 570 and the Penal Sums shall be within the maximum specified for such company in said Circular 570.

END OF SECTION 013326

## SECTION 013326.01 - QUALITY CONTROL PLAN

### PART 1 - GENERAL

#### 1.1 QUALITY CONTROL

- A. The Contractor shall be responsible for the quality of all materials incorporated into the project work and shall be responsible for all costs of testing and certification of same. The Contractor shall provide the City Engineer a list of three (3) local qualified firms for the City to select from to be the Contractor's testing firm.
- B. The Contractor shall provide the Engineer with a Quality Control Plan in which his testing methods/procedures are defined. Said Plan shall meet with the approval of the Engineer and include identification of laboratories, types of testing, and the tentative amount and scheduling of each.

All certifications of tests and/or gradations for materials to be utilized in the work and all quality control testing shall be performed by an independent laboratory (not affiliated with, owned by, or managed by the Contractor). The laboratory shall be accredited by the AASHTO Materials Reference Laboratory for the type of testing performed.

- C. The Owner may perform field Quality Assurance testing; however, such testing shall not relieve the Contractor from the responsibility of Quality Control testing or from supplying certificates from manufacturers or suppliers to demonstrate compliance with the specifications. It is intended that the testing by the Contractor and the Owner be complimentary toward a quality project; however, the Contractor may not assume the Owner will test or that any tests will be done in lieu of the Contractor's own Quality Control testing. In the same sense, the Contractor may not rely on Owner Quality Assurance testing as a basis of acceptance or approval of his work nor may any Owner performed testing be reflected in his submitted plan.

#### 1.2 TEST CRITERIA

- A. The following tests at a minimum shall be included with the Contractor's Quality Control Plan in accordance with the specifications:
  - 1. Aggregates
    - a. For each material and/or different source, the laboratory shall perform soundness, gradation, and other tests for all parameters specified. Aggregates incorporated into concrete or asphalt mixes shall also be tested for moisture content daily.
  - 2. Compaction Tests
    - a. Compaction tests or field density tests shall be taken on all embankment, trench backfill, subgrade, and subbase materials.

- b. Minimum testing shall be as follows:  
Embankment testing shall be at least one (1) test/5000 S.F. of each lift;  
Trench backfill testing shall be at least one (1) test/50 L.F. of each lift;  
Subgrade and/or subbase testing shall be at least one (1) test/200 L.F. of pavement or /5000 S.F. of slabs; subject to greater frequency due to soil conditions or Engineer's direction.
  - c. Proctors or relative density tests shall be performed as often as necessary for the differing soils or granular materials utilized. Proctors shall be run with a minimum of 5 points. Test reports shall show the wet (bulk) weight, dry weight, wet (bulk) density, dry density, moisture content weight and moisture content percentage. Both the dry curve and the wet curve shall be plotted. The source materials shall be tested for gradation, Atterberg limits, shore-hydrometer and moisture content.
3. Concrete Mix Design
- a. For each type of concrete, the laboratory shall perform the necessary mix design providing all test data as required by the specifications.
4. Concrete Field and Laboratory Tests
- a. The laboratory shall cast concrete cylinders and test beams:
    - 1) One set of four cylinders per 50 C.Y. with a minimum of two sets per day. The cylinders shall be broken: one at 7 days, two at 28 days, one at 56 days, unless otherwise directed by the Engineer.
    - 2) One beam per 50 C.Y. with a minimum of two beams per day.
  - b. Temperature and unit weight shall be run on fresh concrete at intervals sufficient for the type of structure being placed and a minimum of once per day. Bulk weight, bucket weight, (tare), net weight, bucket factor (bucket volume) and unit weight shall be recorded on the fresh concrete report. Show all batch weights for yield calculations. Slump and air content tests shall be taken a minimum of one test per 20 C.Y. and at least once per day.
  - c. All field and laboratory testing shall be performed by technicians certified by the American Concrete Institute (ACI) for the type of testing performed.
  - d. Initial cure of all cylinders shall be in a temperature controlled cure box or temperature controlled water tank with a hi-low thermometer. Hi-low temperature readings shall be recorded on the fresh concrete report.
5. Asphalt Mix Design
- a. For each type of asphalt mix, submit job mix formula (JMF) prepared by an ODOT pre-qualified laboratory from tests performed on the aggregates proposed for use.
  - b. Sample and test for gradation and bitumen content as per ODOT 441.
  - c. Asphalt compaction, thickness, and temperature tests shall be performed during asphalt placement per ODOT Item 448.

### 1.3 LABORATORY REPORTS

- A. Reports of laboratory and field tests will be distributed to the Engineer, Owner, and Suppliers within 24 hours of completion.

END OF SECTION 013326.01

## SECTION 013543 - ENVIRONMENTAL PROTECTION

### PART 1 - GENERAL

#### 1.1 UNNECESSARY NOISE, DUST AND ODORS

- A. The Contractor's performance of this contract shall be conducted so as to eliminate all unnecessary noise, dust and odors.

#### 1.2 SEWAGE, SURFACE AND FLOOD FLOWS

- A. The Contractor shall take whatever action is necessary to provide all necessary tools, equipment and machinery to adequately handle all sewage, surface flows and flood flows which may be encountered during the performance of the work. The entire cost of and liability for handling such flows is the responsibility of the Contractor and shall be included in the price for the appropriate item.

#### 1.3 WORK IN FREEZING WEATHER

- A. Written permission from the Engineer shall be obtained before any work is performed which, in the judgment of the Engineer, may be affected by frost, cold, or snow. When work is performed under such conditions, the Contractor shall provide facilities for heating the materials and for protecting the finished work.

#### 1.4 POLLUTION CONTROL

- A. It shall be the responsibility of the Contractor to prevent or limit pollution of air and water resulting from his operations.
- B. The Contractor shall perform work required to prevent soil from eroding or otherwise entering onto all paved areas and into natural watercourses, ditches, and public sewer systems. This work shall conform to all local ordinances and/or regulations, if any, and if not otherwise regulated by local ordinances or regulations shall at a minimum conform to the Ohio EPA General Storm Water NPDES Permit for Construction Activities and the Ohio Department of Natural Resources Rainwater and Land Development manual. This work may consist of but not be limited to construction and continual maintenance of silt fence, bio bag filters, sedimentation traps, stilling basins, check dams, temporary seeding, temporary mulching, erosion mats and other means to clarify waters containing suspended materials from excavations, embankments, cleared and grubbed or stripped areas, stockpiles, well points, and disposal sites and shall be commensurate with the contractor's schedule, sequence of work, means and methods. If a SWPPP plan is not required for the project, the contractor shall at a minimum submit a plan of his proposed erosion control prevention methods for approval by the Owner and/or other regulatory authorities having jurisdiction prior to starting any construction activities which may cause erosion.

- C. The Contractor shall perform work required to prevent dust attributable to his operations from entering the atmosphere. Dust on unsurfaced streets or parking areas and any remaining dust on surfaced streets shall be controlled with water and/or calcium chloride dust palliative as needed.
- D. Any material removed from sanitary or storm sewers shall be disposed in accordance with all applicable regulations.

END OF SECTION 013543

## SECTION 014126 - GENERAL REGULATIONS AND PERMITS

### PART 1 - GENERAL

#### 1.1 ARCHAEOLOGICAL DISCOVERIES

Contractors and subcontractors are required under O.R.C. Section 149.53, to notify the Ohio Historical Society and the Ohio Historic Site Preservation Board of Archaeological Discoveries located in the project area, and to cooperate with those entities in archaeological and historic surveys and salvage efforts if such discoveries are uncovered within the project area.

Contact: Ohio's State Historic Preservation Office  
Diana Welling, Resource Protection & Review Department Manager  
Phone: 1-614-298-2000  
Email: [dwelling@ohiohistory.org](mailto:dwelling@ohiohistory.org)

Should archaeological discoveries or other activities delay progress of the work, an adjustment in contract time will be made.

END OF SECTION 014126



## SECTION 014223 - INDUSTRY STANDARDS

### PART 1 - GENERAL

#### 1.1 ABBREVIATIONS

- A. Abbreviations, as used, designate the following:

AASHTO	-	American Association of State Highway and Transportation Officials
ACI	-	American Concrete Institute
AIEE	-	American Institute of Electrical Engineers
AISC	-	American Institute of Steel Construction
ANSI	-	American National Standards Institute
ASTM	-	American Society of Testing and Materials
AWWA	-	American Water Works Association
CMS	-	Construction and Material Specifications
NEMA	-	National Electrical Manufacturers Association
ODOT	-	Ohio Department of Transportation
ORC	-	Ohio Revised Code
UL	-	Underwriters Laboratories, Inc.

#### 1.2 REFERENCE TO OTHER SPECIFICATIONS

- A. Where reference is made to specifications such as ASTM, AWWA or AASHTO, the latest edition shall be used, unless otherwise noted on the plans or in the specifications.

#### 1.3 CODES AND STANDARDS

- A. All work provided for by these specifications must be installed according to the provisions of the State and local building codes, subject to inspection and acceptance by the State and local inspectors.

END OF SECTION 014223

## SECTION 014323 – QUALIFICATIONS OF TRADESMEN

### PART 1 - GENERAL

#### 1.1 CHARACTER OF WORKMEN AND EQUIPMENT

- A. The Contractor shall employ competent and efficient workmen for every kind of work. Any person employed on the work who shall refuse or neglect to obey directions of the Engineer or their representative, or who shall be deemed incompetent or disorderly, or who shall commit trespass upon public or private property in the vicinity of the work, shall be dismissed when the Engineer so orders, and shall not be re-employed unless express permission be given by the Engineer. The methods, equipment and appliances used on the work and the labor employed shall be such as will produce a satisfactory quality of work, and shall be adequate to complete the contract within the specified time limit.
  
- B. In hiring of employees for the performance of work under this Contract, or any Subcontract hereunder, no Contractor or Subcontractor, nor any person acting on behalf of such Contractor or Subcontractor, shall, by reason of race, sex, creed or color, discriminate against any citizen of the State of Ohio in the work to which the employment relates. No Contractor, Subcontractor, nor any person on their behalf shall, in any manner, discriminate against or intimidate any employee hired for the performance of work under this contract on account of race, creed, sex or color.

END OF SECTION 014323

## SECTION 015213 - FIRST AID

### PART 1 - GENERAL

#### 1.1 AID TO THE INJURED

The Contractor shall keep in their office and on the work site, all articles necessary for giving "First Aid to the Injured." They shall also have standing arrangements for the immediate removal and hospital treatment of any employee or other person who may be injured on the work site.

END OF SECTION 015213

## SECTION 015526 - TEMPORARY TRAFFIC CONTROL DEVICES

### PART 1 - GENERAL

#### 1.1 BARRICADES, SIGNS AND LIGHTS

- A. The Contractor shall employ watchmen on the work when and as necessary. The Contractor shall erect and maintain such strong and suitable barriers and such lights as will effectively prevent the occurrence of any accident to health, limb or property. Lights shall be maintained between the hours of one-half (1/2) hour after sunset and one-half (1/2) hour before sunrise.
- B. No manhole, trench, excavation will be left open awaiting connection or removal at a later date by the Contractor's forces or others, but shall be temporarily backfilled and resurfaced if applicable with a temporary pavement passable to traffic at no additional cost to the Owner.
- C. In addition to other safety requirements, a minimum of four (4) foot high fence will be incorporated around any shaft or manhole or other excavation left open at the end of a day's work.

#### 1.2 MAINTENANCE OF TRAFFIC

- A. The Contractor is required to provide maintenance of traffic in conformance with the Ohio Manual of Uniform Traffic Control Devices and Item 614 of the current Construction and Material Specifications of the Ohio Department of Transportation.
- B. This work shall include providing suitable and satisfactorily trained and properly attired flagmen for use at any location where existing roadway is narrowed to a width of less than two (2) full lanes (18 feet).
- C. The Contractor is also responsible for maintaining local access to all residences and businesses along the route of the construction and to provide whatever temporary materials are necessary to provide a safe, adequate drive surface.
- D. At all boring locations, Contractor shall provide suitable flashers, barricades, and traffic control devices as may be deemed necessary by the Engineer or the responsible authority in the case of the Department of Transportation, Turnpike Commission, or affected railroad. This may extend to maintain facilities on a 24-hour basis until such time as the areas are completely backfilled.

END OF SECTION 015526

## SECTION 016600 - PRODUCT HANDLING AND PROTECTION

### PART 1 - GENERAL

#### 1.1 DELIVERY AND STORAGE OF MATERIALS

- A. The Contractor shall be responsible for delivery and storage of all materials.
- B. The Contractor shall coordinate with the Engineer on the arrangement for storing construction materials and equipment. Deliveries of all construction materials and equipment should be made at suitable times.
- C. The Contractor shall store all materials required for the performance of this contract at sites designated by the Engineer.
- D. All stockpiles shall be neat, compact, completely safe, and barricaded with warning lights if necessary.
- E. Precautions shall be taken so that no shade trees, shrubs, flowers, sidewalks, driveways or other facilities will be damaged by the storage of materials. The Contractor shall be responsible for the restoration of all stockpile sites to their original condition.
- F. Materials, tools and machinery shall not be piled or placed against shade trees, unless they shall be amply protected against injury therefrom. All materials, tools, machinery, etc. stored upon public thoroughfares must be provided with red lights at night time so as to warn the traffic of such obstruction.
- G. Materials shall be so stored as to assure the preservation of their quality and fitness for the work. Stored materials, even though approved before storage, shall again be inspected prior to their use in the work. Stored materials shall be located so as to facilitate their prompt inspection. Approved portions of the construction site may be used for storage purposes and for the placing of the Contractor's plant and equipment, but any additional space required therefore must be provided by the Contractor at their expense. Private property shall not be used for storage purposes without written permission of the property owner or lessee, and copies of such written permission shall be furnished the Engineer. All storage sites shall be restored to their original condition by the Contractor at their expense.

END OF SECTION 016600

## SECTION 017800 - FINAL COMPLIANCE AND SUBMITTALS

### PART 1 - GENERAL

- 1.1 The following forms and related sign-offs shall be documented in accordance with provisions of the contract. These forms shall be completed by the Contractor and approved by the Owner before final retainer is approved for release. Forms for Items A to E will be attached to the Contractor's executed copy of the contract.
- A. Certificate of Substantial Completion (To be submitted at time of Substantial Completion).
  - B. Contractor's Certification of Completion.
  - C. Contractor's Affidavit of Prevailing Wage.
  - D. Consent of Surety Company for Final Payment.
  - E. Affidavit of Final Acceptance Date and Correction Period.

END OF SECTION 017800

## SECTION 017821 - CLEANING AND PROTECTION

### PART 1 - GENERAL

#### 1.1 GENERAL

- A. On or before the completion date for the work, the Contractor shall tear down and remove all temporary structures built by him, all construction plant used by him, and shall repair and replace all parts of existing embankments, fences or other structures which were removed or injured by their operations or by the employees of the Contractor. The Contractor shall thoroughly clean out all buildings, sewers, drains, pipes, manholes, inlets and miscellaneous and appurtenant structures, and shall remove all rubbish leaving the grounds in a neat and satisfactory condition.
- B. As circumstances require and when ordered by the Engineer, the Contractor shall clean the road, driveway, and/or sidewalk on which construction activity under this contract has resulted in dirt or any other foreign material being deposited with an automatic self-contained mechanical sweeper with integral water spray, vacuum and on-board or supplementary containment.
- C. Failure to comply with this requirement when ordered by the Engineer or their representative, may serve as cause for the Engineer to stop the work and to withhold any monies due the Contractor until such order has been complied with to the satisfaction of the Engineer.
- D. As the work progresses, and as may be directed, the Contractor shall remove from the site and dispose of debris and waste material resulting from their work. Particular attention shall be given to minimizing any fire and safety hazard from form materials or from other combustibles as may be used in connection with the work, which should be removed daily.
- E. The Contractor shall wash all windows and other glass surfaces, leaving all areas free from putty marks, paint, etc.
- F. During and after installation, the Contractor shall furnish and maintain satisfactory protection to all equipment against injury by weather, flooding or breakage thereby permitting all work to be left in a new condition at the completion of the contract.

END OF SECTION 017821

## SECTION 017839 - PROJECT RECORDS, DRAWINGS

### PART 1 - GENERAL

#### 1.1 RECORD DRAWINGS

- A. The Contractor shall furnish an authentic set of marked-up drawings showing the installation insofar as the installation shall have differed from the Engineer's drawings. The drawings shall be delivered to the Engineer for making revisions to the original drawings immediately after final acceptance by the Owner.
- B. The Contractor shall furnish dimensioned drawings indicating locations of all underground mechanical and electrical facilities.

#### 1.2 SERVICE CONNECTION RECORDS

- A. The Contractor shall record the location of all service and property connections, new or existing, made to utilities constructed under this contract. Such records shall be turned over to the Owner upon completion of the work. The cost of making such records shall be included in the various unit or lump sum prices stipulated for the various items of the work.
- B. The location of each sewer connection as measured along the sewer from the nearest downstream manhole and its description with respect to the sewer shall be recorded. The record shall include the depth of new stubs for future connections and the depth of existing connections as measured from the surface grade. In addition, the use of any vertical riser pipe shall be noted.
- C. The location of each water connection as measured along the water line from the nearest fire hydrant.

END OF SECTION 017839



## SECTION 312323.13 – COMPACTED BACKFILL

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

#### 1.2 DESCRIPTION OF WORK

- A. The Contractor shall furnish, place and compact all the materials needed from select excavated materials or furnish additional suitable material if the excavated material is deemed unsuitable or the moisture content is not or can not be made to be within acceptable tolerances of optimum moisture to achieve the specified compaction.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. Suitable excavated material as specified in ODOT Item 203.

### PART 3 - EXECUTION

#### 3.1 PLACING

- A. Compacted backfill shall be properly placed in layers sufficient to meet the compaction requirement of 95% of maximum laboratory dry density per ASTM D 698 throughout the entire layer and thoroughly compacted with mechanical compaction equipment with moisture adjustment as needed. Should after settlement occur, the Contractor must add and compact additional material, and he must maintain the backfill at the required finished grade or sub-grade until the project is satisfactorily completed and during the correction period.
- B. Approved mechanical compaction equipment shall be used for tamping backfill. Flooding, jetting or puddling of backfill will not be permitted.

END OF SECTION 312323.13

## SECTION 312323.14 – COMPACTED GRANULAR BACKFILL

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

#### 1.2 DESCRIPTION OF WORK

- A. The Contractor shall furnish, place and compact all the materials needed.

### PART 2 - PRODUCTS

#### 2.1 MATERIAL

- A. Aggregate shall be ODOT 304 crushed limestone. Crushed gravel or slag products are unacceptable.
- B. Contractor shall submit current test reports for the lot(s) of the material to be supplied.

### PART 3 - EXECUTION

#### 3.1 PLACING AND COMPACTING

- A. Compacted granular backfill shall be properly placed in layers sufficient to meet the compaction requirement of 100% of maximum laboratory dry density per ASTM D 698 throughout the entire layer and thoroughly compacted with mechanical compaction equipment with moisture adjustment as needed. Should after settlement occur, the Contractor must add and compact additional material, and he must maintain the backfill at the required finished grade or sub-grade until the project is satisfactorily completed and during the correction period.
- B. Approved mechanical compaction equipment shall be used for tamping backfill. Flooding, jetting or puddling of backfill will not be permitted.

END OF SECTION 312323.14

## SECTION 312333 - UNDERGROUND CONDUIT INSTALLATION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. The Construction Drawings and General Provisions of this Contract including the General and Supplementary Conditions, Specific Project Requirements, Proposal, and all referenced standard specifications apply to work defined in this section.

#### 1.2 DESCRIPTION

- A. This work shall consist of the construction or reconstruction of underground pipe conduits in accordance with these specifications and in reasonable close conformance to the lines and grades shown on the detailed plans or as otherwise established by the Engineer.
- B. This work shall include excavating for the conduit, fittings, and appurtenances; clearing and grubbing and removal of all materials necessary for placement of the conduit except any items paid for separately; furnishing and placing bedding and backfill as required; constructing and subsequently removing all necessary cofferdams, curbs and sheeting; pumping and dewatering; making all conduit joints as required; installing all necessary conduit; joining to existing and proposed appurtenances as required; performing leakage tests as required; restoration of all disturbed facilities and surfaces. The work shall also include the maintenance of existing flow and service to facilities being modified. Procedures for such maintenance shall be as approved by the Engineer prior to any work commencing.

### PART 2 - MATERIALS

#### 2.1 CONDUIT

- A. All conduit utilized shall be of one type and size specified in the proposal meeting the requirements of the detailed material specification.
- B. Shop drawings, catalog cuts, and test certifications may be required by the Engineer for all conduit, fittings, and appurtenances.
- C. Aggregate for the bedding and backfill shall conform to the requirements of the plan detail or as modified in writing by the Engineer. All aggregates shall conform to ODOT 703 for soundness and gradation.
- D. All other materials utilized as part of this work shall meet their respective ASTM requirements.

## PART 3 - EXECUTION

### 3.1 REMOVAL OF STRUCTURES AND OBSTRUCTIONS

#### A. Pavement, Sidewalks, and Curbing

1. Removal of existing pavements, sidewalks, curbing, and similar structures shall end at an existing joint or a sawed joint. Sawed joints shall be straight, neat, and free from chipped or damaged edges.
2. For non-reinforced concrete, the saw cut shall be completely through concrete.
3. For reinforced concrete, the saw cut shall be completely through the steel and concrete.
4. If the concrete is coated with a bituminous surface or other material, the saw cut shall be as specified above.

#### B. Manholes, Catch Basins, and Inlets

1. Existing drainage structures and sanitary manholes designated by the Engineer to be removed shall be completely removed.
2. Manholes designated to be abandoned shall be removed to an elevation of at least 3 ft. below the finished subgrade or ground surface. The remaining void shall be filled with backfill material in accordance with Section 312323.13 - Compacted Backfill.
3. Live sewers connected to structures removed or abandoned shall be rebuilt through the area with new conduit. Sewer flow shall be maintained between removal and replacement operations. Abandoned sewers shall be sealed and made watertight with approved precast stoppers or masonry bulkheads.
4. All castings salvaged from abandoned or removed structures shall remain the property of the Owner and shall be cleaned and transported by the Contractor to a nearby site designated by the Owner or incorporated in the work where called for on the drawings.

#### C. Guardrail and Fence

1. Where necessary, existing guardrail and fence shall be carefully dismantled and stored for reuse or for salvage by the Owner.
2. Posts and other materials not considered salvageable by the Engineer shall be disposed of by the Contractor.
3. The Contractor will be required to replace, at no cost to the Owner, material lost or damaged by negligence or by the use of improper methods.

### 3.2 METHOD OF EXCAVATION

- A. All excavation shall be in open cut unless otherwise permitted by the Engineer. Loosening of material by blasting will not be permitted without written authorization by the Owner specifying both the extent and location of the blasting to be done. If permission is granted the Contractor shall submit in writing their means and methods of blasting to the Owner for approval. Blasting shall not begin until the Owner issues written approval of the means and method of blasting.

- B. Excavation shall be made to undisturbed finish subgrade to the depth below the bottom of the conduit or structure as shown on the Contract Drawings details.
- C. Trenches shall be excavated with vertical sides from the bottom of the trench to one (1') foot above the top of the conduit from which point sides may slope to ground surface, except that, in streets or roadways, trenches shall be excavated with near vertical sides to the top of the trench. Width of trench in the vertical section shall be excavated only as wide as necessary to accommodate a safety box and to provide free working space on each side of the conduit or structure according to the size of the conduit or structure and the character of the ground. In every case there shall be sufficient space between the conduit or structure and the sides of the trench to make it possible to thoroughly ram the bedding around the conduit or structure and to secure tight conduit joints, but in no case more than twelve inches on either side of conduit. In no case, however, shall the width of the trench at the top of the conduit exceed the dimensions as shown on the contract drawings. In no case will it be permitted to excavate conduit trenches with sides sloping to the bottom.
- D. The trench bottom shall be firm and uniform for its full length. Should unstable material be encountered below plan subgrade, it shall be removed to a depth directed by the Engineer. Replacement of the additional excavation shall be with the specified bedding material or as otherwise directed by the Engineer.
- E. In the case the flow line is changed not to exceed one (1) foot or it becomes necessary to remove unstable material in an amount not to exceed one (1) foot, the same shall be done at one contract bid price or amount. When the flow line is lowered more than (1 foot) or if it becomes necessary to remove more than (1 foot) of unsuitable material below the bottom of the trench, compensation will be provided therefore in a supplemental agreement for the excavation and backfill beyond (1 foot).

### 3.3 UNAUTHORIZED EXCAVATIONS

- A. All excavations carried outside of the lines and grades given or specified, together with the disposal of such material, and all excavations and other work resulting from slides, cave-ins, swellings or upheavals shall be at the Contractor's own cost and expense. All spaces resulting from unauthorized excavations or from slides or cave-ins shall be refilled at the Contractor's expense with suitable material as specified in ODOT Item 203, "Roadway Excavation and Embankment" or Section 312323.13, "Compacted Backfill" in designated areas shown on the contract drawings or specified under this Section. Compaction requirements shall be in accordance with these specifications.

### 3.4 SHEETING AND SHORING

- A. The Contractor shall be responsible for supporting and maintaining all excavations required even to the extent of sheeting or shoring the sides and ends of excavations with timber or other satisfactory supports. If the sheeting, braces, shores, stringers, waling timbers, or other supports are not properly placed or are insufficient, the Contractor shall provide additional or stronger supports. The requirements of sheeting or shoring or of the addition of supports shall not relieve the Contractor of their responsibility for their sufficiency. All trench protection and sheeting and shoring must conform to the regulations of both the

Ohio State Industrial Commission (OSIC) and the Federal Occupational Safety and Health Act (OSHA) and will be subject to their respective inspections. All orders of OSIC and OSHA representatives must be complied with by the Contractor.

- B. All sheeting and shoring shall be removed where and when required and, upon its removal, all voids filled. If any sheeting or shoring is ordered to be left in place, it shall be cut-off as directed. In compensation for the sheeting and shoring left in place, if any, shall be by prior written change order.

### 3.5 REMOVAL OF WATER

- A. All conduit shall be installed in a dry and stable trench. The Contractor may pump or otherwise remove any water, sewage, or other liquid that may be found or may accumulate in the trench.
- B. If, in the opinion of the Contractor, dewatering pumps and equipment are required to maintain a dry and stable trench, suitably sized pumps shall be provided to meet the requirements. The manner and spacing of well points shall be at the Contractor's discretion.
- C. Excess water shall not be considered reason for undercut of trench bottom.
- D. The Contractor shall maintain the pumps for the duration of their need including a satisfactory discharge outlet. Power for the pumps shall be electric unless otherwise approved by the Engineer. Noise abatement may be required for any on-site generators in residential areas.

### 3.6 BEDDING FOR LAYING CONDUIT

- A. Bedding shall conform to the requirements of the plan detail unless otherwise modified by the Engineer.
- B. All granular bedding material shall be compacted to 95 percent of maximum laboratory dry density.
- C. All pipe bedding shall be of the gradation(s) specified and be limestone. Slag may not be used and gravel may be used with permission of the Engineer.

### 3.7 LAYING CONDUIT

- A. Except as otherwise permitted by the Engineer, all conduit shall be laid starting at the outlet end. Pressure conduits may be laid from either direction however the joints shall be such that the bell is upgrade or toward normal pressure.
- B. Line and grade for gravity conduits shall be established by the use of sufficient means to maintain acceptable installation tolerances and allow for reasonable checking observation by the Engineer.

- C. Line and grade shall be established and maintained over a length of fifty (50) feet minimum. Cut sheets establishing grade at fifty (50) foot intervals shall be provided to the Engineer prior to beginning work.
- D. The Contractor shall provide sufficient equipment and workers to safely handle and lay all conduit included as part of this work. All storage of materials shall be in a manner as to avoid damage to either surface prior to placement.
- E. The Contractor shall inspect each piece of conduit prior to placement in the trench and any unsatisfactory conduit shall be rejected.
- F. Conduit shall not be laid in water, mud, or any otherwise unsuitable trench. The conduit shall not be pushed into or allowed to fall to the bottom of the trench. Handling of the conduit shall be in conformance to the manufacturer's recommendations.
- G. The conduit shall be kept clean and any open ends of installed conduit shall be closed when work is not in progress.
- H. Jointing of the conduit shall be in accordance to the requirements of the manufacturer and as required by the specification material type. Any deviation from these acceptable methods requires approval of the Engineer.
- I. Testing of joints, where required, shall be done in accordance with the Specification for Testing. Should any section fail to meet test requirements, the Contractor shall make suitable corrections, at their cost, until the requirements are met.

### 3.8 SERVICE CONNECTIONS

- A. In general, and as called for on the drawings, as required or as ordered, provision shall be made in the sewers for service connections by inserting a wye branch for each service connection with a branch size called for by the contract drawings but never less than six (6) inch, in the sewer at location shown, where required or ordered, for sewers to ten (10) feet in depth. For sewers exceeding ten (10) feet in depth, or indicated on the plans, the Contractor shall construct a riser, as per detail, in such manner, that the top of the riser shall be not less than seven (7) feet below grade or at such elevation as to properly receive the required service connection, with full regard to elevation of service sewer and slope from building or structure to the sewer which shall not be less than one percent (1%). Risers are to be encased in sonotube filled with No. 57 Limestone as shown on the contract drawings.
- B. The location of service connections is shown in a general way on the contract drawings. The Owner may also increase the number of connections or delete some connections as the sewer is being built, or increase the size of connections when it deems such advisable.

### 3.9 BACKFILL

- A. Backfill of all conduit trenches shall conform to the requirements of the plans and details, Section 312323.13 "Compacted Backfill", or Section 312323.14 "Compacted Granular Backfill" in that order or as may be specified.
- B. Unless otherwise directed, all forms, bracing and lumber shall be removed during backfilling and the cavities and voids resulting from the removal shall be backfilled and compacted with machine mounted compaction equipment.
- C. The backfill material shall be suitable material as specified in ODOT Item 203 "Roadway Excavation and Embankment" or in Section 312323.13, "Compacted Backfill" and placed in accordance with these specifications. The limits of backfill shall be all excavations not filled by bedding material, conduit and structures. The Contractor must use special care in placing backfill so as to avoid injuring or moving the conduit or structure when compacting the backfill.
- D. Backfill, except in areas where Compacted Backfill is designated on the contract drawings or as specified herein, shall be placed and compacted using machine mounted mechanical tampers in layers sufficient to meet the compaction requirement of 98% of maximum laboratory dry density per ASTM D698.
- E. Where conduit construction crosses beneath a paved roadway, driveway, or similar structure or as shown on the plans, the backfill shall be as described in Section 312323.13, "Compacted Backfill" placed and compacted, using machine mounted mechanical tampers in layers sufficient to meet the compaction requirement of 100% maximum laboratory dry density per ASTM D 698. The top layers, from the elevation of the existing subbase base interface to the surface, shall be ODOT Item 304 Crushed Limestone Aggregate Base placed in conformance with ODOT Item 304 to provide a temporary surface traffic course. Placing of backfill material shall be continued until the entire depth is compacted and the top backfill is finished to the lines and grades call for by the contract drawings, or as ordered by the Engineer. Should after settlement occur, the Contractor must add and compact additional material.
- F. Machine mounted mechanical tamper shall be used for backfill compaction. Flooding, jetting or puddling of backfill will not be permitted.
- G. A selected portion of the excavated materials may be used for backfilling about the conduit or structure. Excavated material in excess of that needed for backfilling and unsuitable material shall be disposed of by the Contractor at their own expense, and the cost of such disposal shall be included in the unit or lump sum prices bid.
- H. The Owner and Engineer do not guarantee nor suggest the in-situ material to be excavated will be suitable or in its present state will consist of the proper moisture content to achieve the compaction requirements. The Contractor shall make their own determination as to the backfill material he will use. Upon request, the Owner will provide access to the site for the Contractor to conduct such investigations and tests deemed necessary to make their determination. No extra payment will be made to dispose of unsuitable material or to



furnish and place suitable material meeting the requirements of Section 312323.13, "Compacted Backfill" or Section 312323.14, "Compacted Granular Backfill".

### 3.10 TESTING AND ACCEPTANCE

- A. Prior to final acceptance of the conduit or the placing of the conduit into service, testing and/or televising may be required.
- B. For all sanitary, water, or other pressured conduits, pressure testing shall be required in accordance to the specifications contained herein. Televising shall be required for all sanitary sewer and may be required for storm sewers as outlined or required by plan note.
- C. Final television inspection of conduit shall be performed by an experienced company and in a format satisfactory to the Owner. Televising shall be done in the presence of the Engineer unless so waived. The Engineer shall be provided with unedited video tapes and two (2) copies of the video log.
- D. Televising shall not be done until all known repairs are completed and the line has been suitably flushed.

### 3.11 SITE RESTORATION

- A. Restoration of the disturbed project area shall begin immediately after backfilling has been completed. All excess material, debris, and excavation shall be disposed of by the Contractor.
- B. Restoration of paved surfaces and of seeded areas shall be done as soon as conditions permit. The manner in which the work shall be done is defined in other specifications or the contract plans.
- C. While payment for site restoration may be included in other items, final acceptance of the underground conduit shall not occur until all work is complete. Where no separate pay items exist for restoration work, the Engineer may determine an appropriate value for this work to be retained until its completion.

END OF SECTION 312333

## SECTION 329200.19 – SEEDING AND MULCHING

### PART 1 – GENERAL

#### 1.1 SUMMARY

- . Installation of seeded areas shall be to the extent shown on Contract Drawings and shall include supplying all seed, topsoil, soil conditioning materials, mulching materials and watering, and the incorporation of these materials into the work as specified.
- A. The Contractor shall place topsoil at the depths specified in those areas requiring seeding. Topsoil shall be furnished by the Contractor.

#### 1.2 SUBMITTALS

- A. Product Data: For the following:
  1. Provide copies of soils tests for both new topsoil (provided) and onsite topsoil for review and approval. This applies to all areas that require seeding, including reconditioned areas.
  2. Provide location of properties from which topsoil is to be obtained, names and addresses of owners, depth to be stripped, and crops grown in the past 2 years.
  3. Provide the name of the seed supplier, name and phone number, list of the seed, including varieties of seed, labels, and an analysis of the seed for review, 4 weeks prior to the start of seeding.
  4. Provide soil amendments information based on soils test requirements.
  5. Hydroseed mixture, mulch and application rates prior to performing the work.

#### 1.1 QUALITY ASSURANCE

- A. Any subcontracted restoration work shall be performed by a qualified firm specializing in landscape work.
- B. The Contractor shall have a soils test done at his expense and analyzed by a state approved testing agency. Soil tests shall be done on both the topsoil stockpiled from the site and new topsoil brought to the site. A minimum of two (2) tests shall be done. The tests shall include percent organic matter, pH, Buffer pH, Phosphorus, Exchangeable Potassium, Calcium, Magnesium, Cation Exchange Capacity and Percent Base Saturation with recommendations for nitrogen, phosphate, potash, magnesium and lime based on plant type and use.

- B. Seed: All seed specified shall meet O.D.O.T. specifications as to the percentage purity, weed seed, and germination. All seed shall be approved by the State of Ohio, Department of Agriculture, Division of Plant Industry, and shall meet the requirements of these specifications.
- D. Packaged Materials: Deliver packaged materials in containers showing weight, analysis, and name of manufacturer. Protect materials from deterioration during delivery, and while stored at site.

#### 1.4 PROJECT CONDITIONS

- B. Utilities: Determine location of underground utilities and perform work in a manner which will avoid possible damage. Hand excavate, as required. Maintain grade stakes set by others until removal is mutually agreed upon by parties concerned.
- C. Excavation: When conditions detrimental to plant growth are encountered, such as rubble fill, adverse drainage conditions, or obstructions, such conditions shall be rectified by the Contractor before planting, with approval from the Owner's Representative.
- D. Soil Stabilization: The Contractor shall provide permanent or temporary soil stabilization to denuded areas within fifteen (15) days after final grade is reached on any portion of the site. Any such area which will not be regraded for longer than fifteen (15) days shall also be stabilized. Soil stabilization includes any measures which protect the soil from the erosive forces of raindrop impact and flowing water. Applications include seeding and/or mulching, or the use of other erosion control measures as directed by the Owner's Representative. If necessary, the Contractor shall coordinate soil stabilization practices with the local Soil and Water Conservation District.
- D. Spring-sown work shall be installed between April 1st and May 30th and Fall-sown work shall be installed between September 1st and October 15th. No permanent seeding shall take place between May 30th and September 1st and between October 15th and April 1st. The dates for seeding may be changed at the discretion of the Owner's Representative.

### PART 2 - PRODUCTS

#### 2.1 TOPSOIL

- A. Topsoil shall be furnished by the Contractor. Stockpiled material, if any, shall be utilized prior to obtaining additional topsoil.
- B. All topsoil shall conform to the U.S. Department of Agriculture soil texturing triangle and shall contain between 3% to 8% organic matter. Topsoil shall be loamy and not consist of more than 38% clay. New topsoil shall be screened to remove clay lumps, brush, weeds, litter, roots, stumps, stones larger than ½" in any dimension and any other extraneous or toxic matter harmful to plant growth.

New topsoil shall be obtained only from naturally well drained sites where topsoil occurs in a depth of not less than 4". Do not obtain from bogs or marshes.

- C. Soil amendments shall be added according to the soils test requirements. Amendments can include, but are not limited to fertilizer, lime, compost, sand, and organic matter. Organic matter shall consist of composted leaves or other approved material.

2.2 SEED

- A. Seed shall be vendor mixed, delivered in original bags and shall be proportioned as follows:

<u>Common Name</u>	<u>Proportion by Weight</u>
Kentucky Blue Grass	50%
Perennial Rye	50%

2.3 MULCH

- A. Mulch shall be clean straw free of seed and weed seed.
  - 1. Anchoring for mulch shall be an ODOT specified SS-1 at 60 gal./ton non-toxic tackifier such as Hydro-stik, or equal, or by securing with a photo degradable netting.
- B. If hydroseeding is used, wood fiber mulching material shall be used and shall consist of virgin wood fibers manufactured expressly from whole wood chips and shall conform to the following specifications.

- Moisture content	10.0% ± 3.0%
- Organic content	99.2% ± 0.8% O.D. Basis
- pH	4.8 ± 0.5
- Water holding capacity, minimum (grams of water per 100 grams of fiber)	1,000

Wood fiber mulching material shall be processed in such a manner as to contain no growth or germination inhibiting factors, and must contain a biodegradable green dye to aid in visual metering during application.

PART 3 - EXECUTION

3.1 PREPARATION - GENERAL

- A. Rough grading to a depth necessary to accept the specified thickness of topsoil must be approved prior to placing topsoil.
- B. Loosen subgrade, remove any stones greater than ½" in any dimension. Remove sticks, roots, rubbish, and other extraneous matter.

- C. Spread topsoil to a minimum depth of 4 inches, to meet lines, grades, and elevations shown on plan, after light rolling and natural settlement. Remove sticks, roots, rubbish, stones greater than 1/2" in any dimension, and other extraneous matter. Topsoil shall be tilled thoroughly by plowing, disking, harrowing, or other approved methods. Add specified soil amendments and mix thoroughly into the topsoil.
- D. Preparation of Unchanged Grades: Where seed is to be planted in areas that have not been altered or disturbed by excavating, grading, or stripping operations, prepare soil for planting as follows: Till to a depth of not less than 6 inches. Apply soil amendments and initial fertilizers as specified. Remove high areas and fill in depressions. Till soil to a homogenous mixture of fine texture, free of lumps, clods, stones, roots and other extraneous matter. Soils test requirements apply here as well.
  - 1. Prior to preparation of unchanged areas, remove existing grass, vegetation and turf. Dispose of such material outside of project limits. Do not turn existing vegetation over into soil being prepared for seed.
 

If necessary, supply and install topsoil in areas where there is no topsoil left after vegetation has been removed.
  - 2. Apply specified soil amendments at rates specified in the soils test and thoroughly mix into upper 2 inches of topsoil. Add topsoil if existing grade has less than 4" of topsoil. Delay application of amendments if planting will not follow within two (2) days.
- E. Fine grade areas to smooth, even surface with loose, uniformly fine texture. Roll, rake, and drag lawn areas, remove ridges and fill depressions, as required to meet finish grades. Remove sticks, roots, rubbish, stones greater than 1/2" in any dimension, and other extraneous matter. Limit fine grading to areas which can be planted immediately after grading.
- F. Moisten prepared areas before planting if soil is dry. Water thoroughly and allow surface moisture to dry before planting lawns. Do not create a muddy soil condition.
- G. Restore areas to specified condition, if eroded or otherwise disturbed, after fine grading and prior to planting.

### 3.2 SEEDING

- A. Do not use wet seed or seed that is moldy or otherwise damaged in transit or storage. Seed shall not be sown when the ground is frozen, muddy, or when weather conditions prevent proper soil preparation, interference with sowing and/or proper incorporation of seed into the soil.
- B. Sow seed using a spreader or hydroseeder. Do not seed when wind velocity exceeds 5 miles per hour. Distribute seed evenly over entire area by sowing 3 lbs. per 1000 S.F. at right angles to each other. Total amount to equal a minimum of 6 lbs. per 1000 S.F.

- C. For seed sown with a spreader, mulch shall be spread uniformly to form a continuous blanket at a rate of 100 lbs. per 1,000 S.F. Mulch shall be 1 1/2" loose measurement over seeded areas and shall be anchored.
- D. Contractor has the option to hydroseed large lawn areas, using equipment specifically designed for such application. The rate of application of wood fiber mulching materials is 40 lbs./1,000 S.F. Contractor shall not hydroseed within close proximity to buildings and structures, or when unfavorable wind conditions may blow the hydroseed material onto the structure. Contractor shall clean all areas not to be seeded of overspray.
- E. The seeded area shall be watered, as soon as the seed is applied, at the rate of 120 gallons per 1000 square feet. The water shall be applied by means of a hydroseeder or a water tank under pressure with a nozzle that will produce a spray that will not dislodge the mulching material. Cost of this watering shall be included in the cost of seeding and mulching.

### 3.3 DORMANT SEEDING METHOD

- A. Seeding shall not take place from October 15 through November 20. During this period prepare the seed bed, add the required amounts of lime and fertilizer, and other amendments, then mulch and anchor.
- B. From November 20 through April 1, when soil conditions permit, prepare the seed bed, lime and fertilize, apply the selected seed mixture, mulch, and anchor. Increase the seeding rate by 50 percent.

### 3.4 RECONDITIONING EXISTING LAWNS

- A. A soils test shall be required for existing lawns prior to any reconditioning.
- B. Recondition all existing lawn areas damaged by Contractor's operations including storage of materials and equipment and movement of vehicles. Also recondition existing lawn areas where minor regrading is required.
- C. Provide soil amendments as called for in the soils test.
- D. Provide new topsoil, as required, to fill low spots and meet new finish grades.
- E. Cultivate bare and compacted areas according to the topsoil specifications.
- F. Remove diseased and unsatisfactory lawn areas; do not bury into soil. Remove topsoil containing foreign materials resulting from the Contractor's operations, including oil drippings, stone, gravel, and other loose building materials.
- G. All work shall be the same as for new seeding.
- H. Water newly planted seed areas. Maintenance of reconditioned lawns shall be the same as maintenance of new lawns.

### 3.5 ESTABLISHMENT

- A. Maintain work areas as long as necessary to establish a uniformly close stand of grass over the entire lawn area. A uniformly close stand of grass is defined as the seeded areas having 90%+ coverage of grass at 60 days after seeding. 90%+ coverage is defined as very little or no dirt showing when seeded area is viewed from directly overhead.
- B. Maintain lawns by watering, fertilizing, weeding, mowing, trimming, and other operations such as rolling, regrading and replanting as required to establish a smooth acceptable lawn.
  - 1. Mowing
    - a. Mow lawn areas during the period of maintenance to a height of 2 inches whenever the height of the grass becomes 3 inches. A minimum of 3 mowings is required during the period of maintenance.
  - 2. Refertilizing
    - a. Distribute fertilizer on the seeded area between August 15 and October 15, during the period when grass is dry, and in accordance with the manufacturer's recommendations. The fertilizer shall be as specified in the soils test.
  - 3. Reseeding
    - a. Reseed with the seed specified for the original seeding, at the rate of 4 lbs. per 1,000 S.F. in a manner which will cause minimum disturbance to the existing stand of grass and at an angle of not less than 15 degrees from the direction of rows of prior seeding.
  - 4. Watering
    - a. The Contractor shall keep all work areas watered daily to achieve satisfactory growth. Water shall be applied at a rate of 120 gallons per 1,000 square feet. If water is listed as a pay item, it shall be separately paid for based on the actual amount of water used, measured in thousands of gallons.
  - 5. Any mulching which has been displaced shall be repaired immediately. Any seed work which has been disturbed or damaged from the displacement of mulch shall be repaired prior to remulching.

### 3.6 INSPECTION AND ACCEPTANCE

- A. When seeding work is complete and an acceptable stand of growth is attained, the Contractor shall request the Owner's Representative to make an inspection to determine final acceptance.
- B. Acceptance shall be based upon achieving a vigorous uniformly stand of the specified grasses. If some areas are satisfactory and some are not, acceptance may be made in blocks, provided they are definable or bounded by readily identified permanent surfaces, structures, or other reference means. Partial acceptance decisions may be made by the Owner's Representative. Excessive fragmentation into accepted and unaccepted areas shall not be allowed. Unaccepted areas shall be maintained by the Contractor until acceptable.

- C. No payment shall be made until areas are accepted.
- D. All seeded areas shall be guaranteed for one full growing season to commence upon final acceptance of the areas.

END OF SECTION 329200.19



## SECTION 330130 - MISCELLANEOUS TEMPORARY FACILITIES

### PART 1 - GENERAL

#### 1.1 MAINTENANCE OF SANITARY FLOWS

- A. The Contractor for this contract shall be responsible for maintaining all sanitary flows through the existing sanitary sewerage systems. Provisions shall be made for temporary pumping and/or storage of sanitary flows during periods of sewer and manhole reconstruction, or when flows must be interrupted to make connections to the new facilities as directed by the Engineer.

END OF SECTION 330130

## SECTION 330130.02 - SEWER LINE CLEANING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division-1 Specifications, apply to work of this section.

#### 1.2 DESCRIPTION OF WORK

- A. The intent of sewer line cleaning is to remove foreign materials from the lines and restore the sewer to a minimum of 100% of the original carrying capacity or as required for proper lining of the pipe or seating of internal pipe joint sealing packers. Since the success of the other phases of work depends a great deal on the cleanliness of the lines, the importance of this phase of the operation is emphasized. It is recognized that there are some conditions such as broken pipe and major blockages that prevent cleaning from being accomplished or where additional damage would result if cleaning were attempted or continued. If in the course of normal cleaning operations, damage does result from pre-existing and unforeseen conditions such as broken pipe, the Contractor will not be held responsible.
- B. The intent of chemical root treatment is to kill tree roots in sanitary/storm sewer lines and to inhibit root regrowth without damaging the trees, the environment, or the treatment plant.

#### 1.3 QUALITY ASSURANCE

- A. In addition to requirements of these specifications, comply with manufacturer's instructions and recommendations for work.

#### 1.4 SUBMITTALS

- A. Equipment Data: Submit a listing of equipment to be used on the project. Provide equipment operating instructions if requested by the Owner.
- B. Chemical Root Removal Data:
  - 1. Submit manufacturer's technical data and application instructions.
  - 2. Submit Material Safety Data Sheet(s) for the chemicals to be used in the root removal process.
  - 3. Submit a specimen product label of foaming material to be used in chemical root treatment.

## PART 2 - PRODUCTS

### 2.1 GENERAL

- A. All equipment and material shall be of a type that has been in general use for a period of five (5) years. Work performed with experimental equipment or material will not be permitted without prior written consent of the Owner.

### 2.2 CLEANING EQUIPMENT

- A. **Hydraulically Propelled Equipment:** The equipment used shall be of a movable dam type and be constructed in such a way that a portion of the dam may be collapsed at any time during the cleaning operation to protect against flooding of the sewer. The movable dam shall be equal in diameter to the pipe being cleaned and shall provide a flexible scraper around the outer periphery to insure removal of grease. If sewer cleaning balls or other equipment which cannot be collapsed is used, special precautions to prevent flooding of the sewers and public or private property shall be taken.
- B. **High-Velocity Jet (Hydrocleaning) Equipment:** All high-velocity sewer cleaning equipment shall be constructed for ease and safety of operation. The equipment shall have a selection of two or more high-velocity nozzles. The nozzles shall be capable of producing a scouring action from 15 to 45 degrees in all size lines designated to be cleaned. The gun shall be capable of producing flows from a fine spray to a solid stream. The equipment shall carry its own water tank, auxiliary engines, pumps and hydraulically driven hose reel.
- C. **Mechanically Powered Equipment:** Bucket machines shall be in pairs with sufficient power to perform the work in an efficient manner. Machines shall be belt operated or have an overload device. Machines with direct drive that could cause damage to the pipe will not be allowed. A power rodding machine shall be either a sectional or continuous rod type capable of holding a minimum of 750 feet of rod. The rod shall be specifically heat-treated steel. To insure safe operation, the machine shall be fully enclosed and have an automatic safety clutch or relief valve.

### 2.3 CHEMICAL FOAM ROOT REMOVAL

- A. The chemical root treatment material shall be EPA registered and labeled for use in sewer lines and acceptable to the state agencies having jurisdiction over its use.
- B. The active ingredient for killing roots shall be a nonsystemic herbicide which will kill roots at low concentrations but will not permanently affect parts of the plant distant from the treated roots. The active ingredient must be spontaneously detoxified by natural chemical/biochemical processes following its use. The active ingredient shall not adversely affect the performance of wastewater treatment plants.

- C. The active ingredient for inhibiting root regrowth in sanitary sewers shall inhibit root cell growth on contact but shall not be transported so as to damage other portions of the plant. The material shall form a persistent chemical barrier suppressing the growth of root tips. The material shall be sufficiently stable under conditions of use to provide protection for 12 months but shall be subject to decomposition in wastewater treatment plants without disturbing plant processes.
- D. The root treatment material shall contain emulsifiers to degrease root masses and remove fatty acids from root tissue and surfactants to convert an aqueous solution of the root treatment agent into a volatile foam.

## PART 3 - EXECUTION

### 3.1 CLEANING PRECAUTIONS

- A. During sewer cleaning operations, satisfactory precautions shall be taken in the use of cleaning equipment. When hydraulically propelled cleaning tools (which depend upon water pressure to provide their cleaning force) or tools which retard the flow in the sewer line are used, precautions shall be taken to ensure that the water pressure created does not damage or cause flooding of public or private property being served by the sewer.
- B. When possible, the flow of sewage in the sewer shall be utilized to provide the necessary pressure for hydraulic cleaning devices. When additional water from fire hydrants is necessary to avoid delay in normal work procedures, the water shall be conserved and not used unnecessarily.
- C. No fire hydrant shall be obstructed in case of a fire in the area served by the hydrant.

### 3.2 LIGHT SEWER CLEANING

- A. The designated sewer laterals shall be cleaned using hydraulically propelled, high-velocity jet, or mechanically powered equipment. Selection of the equipment used shall be based on the conditions of lines at the time the work commences. The equipment and methods selected shall be satisfactory to the Engineer. The equipment shall be capable of removing dirt, grease, rocks, sand, and other materials and obstructions from the sewer lines and manholes.
- B. If cleaning of an entire section cannot be successfully performed from the cleanout or mainline, the equipment shall be set up on the other access point and cleaning again attempted. If, again, successful cleaning cannot be performed or the equipment fails to traverse the entire lateral, it will be assumed that a major blockage may exist, the cleaning effort shall be suspended, and the Engineer shall be notified.

### 3.3 HEAVY SEWER CLEANING

- A. After the sewers have attempted to be cleaned by standard light sewer cleaning methods approved by the Engineer or if in the opinion of the Engineer the sewer could not be cleaned by the light cleaning method(s), the Contractor shall be directed to clean the sewer using Heavy Cleaning methods previously submitted and approved.
- B. Roots shall be removed from the laterals where root intrusion occurs. Special attention should be used during the cleaning operation to assure complete removal of roots from the joints. Any roots which could prevent proper lining of the pipe shall be removed.
- C. Mechanical procedures may include the use of equipment such as rodding machines, bucket machines and winches using root cutters and porcupines, and equipment such as high-velocity jet cleaners.
- D. Chemical root treatment shall be used when directed by the Owner.
  - 1. The Contractor's attention is directed to the safety requirements and precautions associated with the use of the root treatment material. The Contractor shall use precautions for the protection of all persons, vegetation, animals and property. The Contractor is responsible for damage to private property and vegetation.
  - 2. The Contractor is required to be knowledgeable of and in compliance with federal and state requirements relative to the root treatment material and its use. Compliance with federal and state law shall supersede compliance with the provisions of this contract.
  - 3. All mixing/application procedures for chemical root treatment shall be consistent with the latest standards, requirements and recommendations of the manufacturer of the chemical root treatment material used. Mixing and application of the root treatment material shall be done under the supervision of a state-certified pesticide (herbicide) applicator as required by law.
  - 4. When the root tips are damaged or removed by sewer line cleaning, chemical treatment will be less effective. Consequently, no mechanical cleaning is recommended in lines prior to chemical root treatment unless extensive grease, root masses, or debris preclude proper application of the material.
  - 5. Sewer service shall generally not be interrupted during root treatment. In situations where it is necessary to shut down upstream pumping stations of block/bypass upstream flows, the Contractor shall coordinate their activities with the Engineer and Owner and do the work at night or during periods of low flow.
  - 6. All materials shall be delivered to the site in undamaged, unopened containers bearing the manufacturer's original label. Mixing of the root treatment material shall be done no more than 12 hours prior to use. The water used shall be clear and free of acid, alkali, oxidizing agents, oil, or other organic materials. Mixing water temperature shall be between 40°F and 80°F.
  - 7. Where conditions permit, the volume of foam shall be sufficient to completely fill the air space above the flow, manhole to manhole. In all cases, the volume of foam delivered to the sewer line shall be sufficient to attach to and permeate all root masses.

8. The foam shall be applied at sufficient pressure to penetrate a minimum of 5 feet into service connections.
9. Root Removal: The Contractor shall wait a minimum of 90 days from application of the foam to removal of roots unless otherwise directed by the Engineer.

E. All roots must be removed prior to grouting or lining. If roots are detected during either of grouting or lining, the Contractor shall remove their equipment and reclean the line to ensure root removal. This work shall be performed at no additional cost to the Owner if the manhole section was previously cleaned as a pay item.

### 3.4 MATERIAL REMOVED

- A. All sludge, dirt, sand, rocks, grease, and other solid or semisolid material resulting from the cleaning operation shall be removed from the sewer system.
- B. Passing material from manhole section to manhole section, which could cause line stoppages, accumulations of sand in wet wells, or damage pumping equipment, shall not be permitted.
- C. When necessary or when directed by the Engineer, an approved dam or weir shall be constructed in the downstream manhole in such a manner that solids and debris will be trapped and retained. The cost of such a dam or weir shall be included in the cost of cleaning.

### 3.5 DISPOSAL of MATERIALS

- A. All solids or semisolids resulting from the cleaning operations shall be removed from the site and disposed of at a location approved by the Owner.
- B. Trucks hauling solids or semisolids from the site shall be watertight so that no leakage or spillage will occur.
- C. All materials shall be removed from the site no less often than at the end of each workday.
- D. Under no circumstances will the Contractor be allowed to accumulate debris, etc., on the site of work beyond the stated time, except in totally enclosed containers and as approved by the Owner.

### 3.6 FINAL ACCEPTANCE

- A. Acceptance of sewer line cleaning shall be made upon the successful completion of the television inspection and shall be to the satisfaction of the Owner.
- B. If TV inspection shows the cleaning to be unsatisfactory, the Contractor shall be required to reclean and reinspect the sewer line at no additional expense to the City.

- C. In areas where television inspection is not performed, the Engineer may require the Contractor to pull a double squeegee (with each squeegee the same diameter as the sewer) through each manhole section as evidence of adequate cleaning.

END OF SECTION 330130.02

## SECTION 330130.17 - TELEVISION INSPECTION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division-1 Specifications, apply to work of this section.

#### 1.2 DESCRIPTION OF WORK

- A. After cleaning or when otherwise specified, the manhole sections shall be visually inspected by means of closed-circuit television (CCTV). The inspection will be done one manhole section at a time and the flow in the section being inspected will be suitably controlled.

#### 1.3 QUALITY ASSURANCE

- A. In addition to requirements of these specifications, comply with manufacturer's instructions and recommendations for work.

#### 1.4 SUBMITTALS

- A. Equipment Data: Submit equipment manufacturer's technical data and operation instructions for the televising and recording equipment to be used.
- B. Report: Submit sample televising inspection log report for review and approval of content and format.

### PART 2 - PRODUCTS

#### 2.1 GENERAL

- A. The camera, television monitor, and other components of the video system shall be capable of producing picture quality to the satisfaction of the Owner's Representative, and if unsatisfactory, equipment shall be removed and no payment will be made for an unsatisfactory inspection.

#### 2.2 MATERIAL

- A. CD-Rs (Read only) 650MB or DVD-Rs (Read only) 4.7GB meeting the requirements of the ISO 9660 standard. CDs may be used to submit digital photos and inspection reports in JPEG format, while DVDs may be used to submit video recordings in MPEG format, and digital photos and inspection reports in JPEG format.
- B. Copies of proprietary software (Read only) that may be necessary to view video and inspection reports concurrently shall be provided to the Engineer at no additional cost.



## 2.3 EQUIPMENT

- A. The television camera used for the inspection shall be one specifically designed and constructed for such closed-circuit sewer pipe inspection. Lighting for the camera shall be suitable to allow a clear picture of the entire periphery of the pipe. The camera shall be operative in 100% humidity conditions. The camera shall televise and transmit the image in color, have an accurate footage counter display and the mainline camera (if used) shall have pan and tilt capabilities.
- B. The propulsion system for large diameter pipes shall be either a transporter, skid and winch arrangement, or with special approval from the Owner, a floatation device as recommended by the equipment manufacturer.
- C. The recording system shall be Digital utilizing a high end industrial grade computer system with a shuttle cartridge, both with the capability for annotating and narrating the video image, and for producing digital photographs (JPEG format) or MPEG snippets of the video image.

## PART 3 - EXECUTION

### 3.1 LARGE DIAMETER(MAINLINE) PIPE PROCEDURE

- A. Normally, televising is performed with the camera traveling with the flow and is set up in the upstream manhole. Where the setup causes the camera lens to be positioned a distance upstream or downstream of the manhole wall, the operator shall make a visual observation of that portion of the sewer pipe not captured on the video and record the observations by voice over on the video.
- B. The height of the camera shall be adjusted so that the lens is at the center of the pipe to be televised.
- C. The camera will be moved through the line in either direction at a moderate rate, stopping when necessary to permit proper documentation of the sewer's condition. In no case will the television camera travel at a speed greater than 30 feet per minute. Transporters, manual winches, power winches, TV cable, and powered rewinds or other devices that do not obstruct the camera view or interfere with proper documentation of the sewer conditions shall be used to move the camera through the sewer line.
- D. The camera will be moved to the far manhole and the recording shall show the condition of the manhole trough (invert). The operator shall make a visual observation of the far manhole. Connecting pipes and manhole defects not captured on the video shall be recorded by voice over on the video and documented in the television inspection log.
- E. Connections to the sewer shall be viewed using the pan and tilt capabilities of the mainline camera. The pan and tilt motion shall be a smooth transition from the mainline pipe to the connection with the camera remaining in an upright (12:00) position. Once the camera is viewing in the direction of the connection, the camera head may be rotated to enhance the

view. Spiral rotation of the camera head as it approaches a connection is prohibited. The operator should also avoid 360 degree rotations when returning the camera to its “home” position. The camera shall be positioned in the sewer at a location which maximizes the sight distance up the connecting pipe. The acceptable length of viewing shall be a distance of approximately 6 feet, or to the end of the pipe (if capped), or to the first bend (if a wye).

- F. The camera head shall remain in an upright (12:00) position until such time that connections, leaking joints, cracked pipe or other defects are encountered. The camera head shall then be panned and tilted to provide a better view. At no time shall the camera be advanced while the camera head is not in and upright position or during its return to the “home” position.
- G. If, during the inspection operation, the television camera will not pass through the entire sewer section, the Contractor shall perform a reverse setup (set up their equipment so that the inspection can be performed from the opposite manhole). If, again, the camera fails to pass through the entire sewer section, the sewer section will be referred to the Engineer for evaluation.
- H. When manually operated winches are used to pull the television camera through the line, a suitable means of communication shall be set up between the two manholes of the section being inspected to insure good communication between members of the crew.
- I. The importance of accurate distance measurements is emphasized. Measurement for location of defects shall be by means of a footage counter with the value displayed on the video. The footage counter shall be set such that zero is the center of the beginning manhole. Marking on the cable, or the like, which would require interpolation for depth of manhole, will not be allowed. Accuracy of the footage counter shall be checked above ground by use of a walking meter, roll-a-tape, or other suitable device. The footage counter shall be calibrated to an accuracy of +/- ½ foot or that which is satisfactory to the Engineer.
- J. Digital Documentation of the television results shall be as follows:
  - 1. Television Inspection Logs: Electronically produced location records may be integrated with the video file or may be a stand alone JPEG file. Electronic copies shall be kept by the Contractor and will clearly state a description of the location in relation to an adjacent manhole of each infiltration point observed during inspection. In addition, other points of significance such as locations of building sewers, unusual conditions, roots, sewer connections, broken pipe, presence of scale and corrosion, and other discernible features will be recorded and a copy of such records will be supplied to the Owner. Each feature called out on the inspection log shall be identified as to its location on the video by means of a footage counter. The television inspection log shall be named (if not integrated with the video) to reflect the corresponding manhole section.

2. Digital Video Recordings: The purpose of the digital recording shall be to supply a permanent audio/visual documentation of the sewer system and its structural condition that may be replayed at a later date. Digital video recording playback shall be at the same speed that it was recorded. All the standard motion playback features (such as those available in a Windows operating system and in accordance with ISO 9660) shall be incorporated.

END OF SECTION 330130.17

## SECTION 330130.19 - SERVICE CONNECTION TELEVISIONING AND REHABILITATION

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification sections, apply to work of this section.

#### 1.2 DESCRIPTION OF WORK

- A. Work includes televising and sealing service connections within the rehabilitation work limits. The pipe shall be sealed by lining with cured-in-place pipe. When structurally failed and/or when authorized by the Engineer, service connections shall be replaced under the corresponding sections of these specifications.
- B. The service connection may be entered either through the mainline sewer, from a test tee or excavated pit. If a test tee does not exist on the service connection, one will be constructed as authorized by the Engineer.
- C. The remainder of the service connection to and through the house to its terminus may be televised and videotaped, if authorized by the Engineer.
- D. When directed, work shall also include attaching a transmitter to the camera and tracking the location of the service connection on the ground surface.

#### 1.3 QUALITY ASSURANCE

- A. In addition to requirements of these specifications, comply with manufacturer's instructions and recommendations for work.

#### 1.4 SUBMITTALS

- A. Submit televising and rehabilitation equipment and product data in accordance with the respective sections of these specifications.

#### 1.5 SERVICE CONNECTION REHABILITATION LIMIT

- A. Length of service connections to be rehabilitated shall be from the mainline sewer to the test tee, right-of-way line, or as authorized by the Engineer.

## PART 2 - PRODUCTS

### 2.1 GENERAL

- A. The equipment and products used in Service Connection Televising and Rehabilitation shall be similar to the equipment and products used for the respective work in main line sewers. Allowances will be made for modifications necessary to work in the smaller diameter pipes associated with service connections.
- B. Cameras for televising the service connection from the mainline sewer shall be Cues Lateral Inspection System, or an approved equal.
- C. The pipe locating system shall use a transmitter and receiver capable of accurately location the service connection from above ground.

## PART 3 - EXECUTION

### 3.1 GENERAL

- A. The execution of work in Service Connection Televising and Rehabilitation shall be similar to the respective work in main line sewers. Additional requirements are listed as follows.

### 3.2 HOMEOWNER NOTIFICATION

- A. The Contractor shall notify the homeowner at least 48 hours prior to commencement of any work on the service connection.
- B. The notification shall explain to the homeowner what work is to be done to the service connection, when the work is scheduled to be performed, and what precautions the homeowner must take to prevent backup of sewage into the house.

### 3.3 SERVICE CONNECTION TELEVISIONING

- A. The service connection televising shall be performed by closed circuit television equipment in accordance with Sewer Line Televising.
- B. When televising from the test tee, the service connection shall be cleaned and roots removed in accordance with Sewer Line Cleaning. The cost of this work shall be included in the cost of Service Connection Television Inspection.
- C. When directed to locate the service connection, the pipe locating system shall be used and the location of the service connection at the right-of-way line shall be marked on the surface of the ground and recorded with reference measurements approved by the Engineer.

- D. During service connection televising work, the following information shall be recorded on the video tape. The reference point from which distances are measured shall be approved by the Engineer.
  - 1. Address of the house served by the service connection.
  - 2. Type service connection, whether storm or sanitary.
  - 3. Location and coding of all defects in accordance with NASSCO's Lateral Assessment Certification Program (LACP). This shall include cracked pipe, broken pipe, root intrusion and any other defects in the service connection.
  - 4. Location where the service connection changes size and or material.
  - 5. Location of any branch pipes.
  - 6. Location of any other significant feature observable in the service connection.

### 3.4 CURED-IN-PLACE PIPE

- A. Any branch pipes on the service connection shall be brought to the attention of the Engineer. An investigation will be made and disposition determined for the branch prior to lining the service connection.
- B. After lining, seal the ends of the CIPP to the host pipe to prevent movement of groundwater along the periphery of the pipe.
- C. The liner/T-liner shall cover the entire service connection including wye or tee joint.

### 3.5 RECORDS

- A. During the service connection televising and rehabilitation work, records shall be kept which will include:
  - 1. Identification of the sewer section containing the service connections.
  - 2. Location (footage) of each service connection as measured from the upstream manhole.
  - 3. Address of the building connected to the service connection.
  - 4. Details of the work performed on the service connection.

### 3.6 FINAL ACCEPTANCE

- A. After rehabilitation work is completed, the Contractor shall provide the Owner with a videotape showing both the before and after conditions.
- B. Any defects resulting from rehabilitation work which will affect, the intended use, integrity or strength of the service connection shall be repaired, at the Contractor's expense, in a manner mutually agreed by the Owner and the Contractor.
- C. Where CIPP is used for rehabilitation, sufficient portions of the trimmings of each end of the CIPP section shall be marked as to location and given to the Engineer for measurements of thickness and testing of structural properties.

- D. After the installation work has been completed and all testing acceptable, the Contractor shall clean up the entire project area. All excess material and debris not incorporated into the permanent installation shall be disposed of by the Contractor.

END OF SECTION 330130.19

## SECTION 330130.74 – CIPP CONNECTION WITH LATERAL

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division-1 Specifications, apply to work of this section.
- B. Other Sections Referenced:
  - 1. Section 330130.01 – Sewer Collection System Rehabilitation
  - 2. Section 330130.02 – Sewer Line Cleaning
  - 3. Section 330130.03 – Sewer Flow Control
  - 4. Section 330130.17 – Television Inspection
- C. Other documents which should be considered part of and include in these specifications
  - 1. ASTM F-2561 Standard Practice for Rehabilitation of a Sewer Service Lateral and Its Connection to the Main Using a One-Piece Main and Lateral Cured-In-Place Liner.
  - 2. ASTM D-790 Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials.
  - 3. ASTM D-792 Standard Test Methods for Density and Specific Gravity of Plastics by Displacement.
  - 4. ASTM D-2990 Standard Test Methods for Tensile, Compressive, and Flexural Creep and Creep-Rupture of Plastics.
  - 5. MD5813 Standard Specification for Cured-in Place Thermosetting Resin Sewer Pipe.

#### 1.2 DESCRIPTION OF WORK

- A. This specification covers material requirements, installation practices, and test methods for the reconstruction of a sewer service lateral pipe and the main connection without excavation. The lateral pipe is renovated remotely from the main pipe to a sewer cleanout located within the public right of way. The pipe renovation shall be accomplished by the inversion and inflation of a resin impregnated, single-piece lateral and main connection liner assembly. The liner assembly is pressed against the lined main pipe by inflation of a bladder and held under pressure until the thermo-set resin has cured. When cured, the liner shall extend over a predetermined length of the service lateral and the full circumference of the main pipe connection forming a continuous, single-piece, tight fitting, corrosion resistant and verifiable non-leaking cured in-place pipe (CIPP) inclusive with gasket seals. The Materials and Installation practices shall adhere to the minimum requirements of ASTM F2561-11 “Standard Practice for Rehabilitation of a Sewer Service Lateral and its Connection to the Main Using a One-Piece Main and Lateral Cured-in Place Liner.”

#### 1.3 QUALITY ASSURANCE

- A. In addition to requirements of these specifications, comply with manufacturer's instructions and recommendations for work.



## 1.4 SUBMITTALS

- A. Submit the latest edition and any revisions thereto of the manufacturer's technical data and installation instructions.
- B. Submit Material Safety Data Sheet(s) for the resins, any other chemical additives, and any other chemicals used in the CIPP system.
- C. Submit certified copies of all test reports on the properties of the proposed resin materials prior to their use. Tests shall be performed by an approved independent testing laboratory or other approved source.
- D. Submit design calculations for the CIPP material thickness for each section of the pipe to be rehabilitated.

## 1.5 QUALIFIED BIDDER

- A. A qualified bidder for installing a mainline/lateral connection and lateral repair system shall use a Manufactured System that has a minimum of a five-year history of satisfactory performance and the Manufactured System shall have performed a minimum of 10,000 successful installations during this time period in the U.S., including 300,000 feet of lateral lining. Bidders shall be prepared to submit a list of installation projects, numbers of connections sealed and lateral footage lined providing contact names, addresses, and telephone numbers for reference.

## PART 2 - PRODUCTS

### 2.1 GENERAL

- A. All equipment and material shall be of a type that has been generally been in use for a period of five (5) years. Work performed with experimental equipment or material will not be permitted without prior written consent of the Owner.
- B. The reconstruction shall be accomplished using a non-woven textile tube of particular length and a thermo-set resin with physical and chemical properties appropriate for the application. The lateral tube located within a translucent inversion bladder is vacuum impregnated with the synthetic resin and is then placed inside of a protective carrying device. The mainline portion of the liner is physically attached to the lateral portion and is affixed around a rigid "T" launching device. The protective "T" launching device is winched into the existing sewer. When the "T" launching device is properly positioned at the lateral connection, the mainline bladder is inflated by pressurized air that presses the main liner against the host pipe. The lateral portion is then inverted up through the lateral service line by the action of the inversion bladder. Once the resin-saturated liner is cured, the inversion bladder and launching/carrying devices are removed.

## 2.2 MATERIAL

- A. Liner Assembly - The liner assembly shall be continuous in length and consist of one or more layers of absorbent textile material i.e. needle punched felt, circular knit or circular braided tubes that meet the requirements of ASTM F1216 and ASTM D5813 Sections 6 and 8. No intermediate or encapsulated elastomeric layers shall be in the textile that may cause de-lamination in the cured in-place pipe. The textile tube and sheet shall be constructed to withstand installation pressures, have sufficient strength to bridge missing pipe segments, and flexibility to fit irregular pipe sections. The wet-out textile tube and sheet shall meet ASTM F 1216, 7.2 as applicable, and shall have a uniform thickness and 5% to 10% excess resin distribution that when compressed at installation pressures will meet or exceed the design thickness after cure.
- B. Mainline Liner Tube - The main sheet will be flat with one end overlapping the second end and sized accordingly to create a circular lining equal to the inner diameter of the main pipe. The interior of the textile sheet shall be laminated with an impermeable, translucent flexible membrane. The textile sheet before insertion shall be permanently marked on the membrane as a "Lateral Identification" correlating to the address of the building the lateral pipe provides service.
- C. Lateral Liner Tube - The exterior of the lateral liner tube shall be laminated with an impermeable, translucent flexible membrane. Longitudinal seams in the tube shall be stitched and thermally sealed. The lateral tube will be continuous in length and the wall thickness shall be uniform. The lateral tube will be capable of conforming to offset joints, bells, disfigured pipe sections and pipe diameter transitions up to 20% of the connection diameter.
- D. Mainline Connection - The main tube and lateral tube shall be formed as a one-piece assembly by stitching the lateral tube to the main sheet aperture. The connecting end of the lateral tube shall be shaped to match the aperture and curvature of the main tube. The lateral tube and main tube are connected by stitching and sealing the stitching using a flexible UV cured adhesive/sealant. The main and lateral tubes are assembled in the shape of a "T" or WYE with corresponding dimensions. Submittals for the liner assembly must include the manufacturers test protocol and tests data that certifies the connection between the liner tubes is leak-free, when subjected to a controlled vacuum leak test.
- E. Gasket Seals - The mainline connection shall include a seamless molded flange shaped end seal gasket attached to the main liner tube by use of stainless steel snaps. The lateral tube shall include an O-ring gasket attached six-inches from the upstream terminating end of the lateral tube.
- F. End Seal Test Data - The hydrophilic gaskets must include test data that reports substantial water-tightness at the terminating ends of a CIPP when subjected to hydrostatic loading that simulates subterranean conditions. Gasket seal submittals must include tests data simulating hydration/ dehydration conditions for a period of 10,000-hours and the test results must successfully demonstrate and document long-term performance without deterioration, loss of material, flexibility, and expansion of the gasket during repeated cycles of hydration and dehydration.

- G. Bladder Assembly - The liner assembly shall be surrounded by a second impermeable, inflatable, flexible translucent membrane (translucent bladder) that will contain the resin and facilitate vacuum impregnation while monitoring of the resin saturation during the resin impregnation (wet-out) procedure.

2.3 RESIN SYSTEM

- A. The resin/liner system shall conform to ASTM D5813 Section 8.2.2 10,000 hour test.
- B. The resin shall be a corrosion resistant polyester, vinyl ester, epoxy or silicate resin and catalyst system that when properly cured within the composite liner assembly, meets the requirements of ASTM F1216, the physical properties herein, and those which are to be utilized in the design of the CIPP, for this project.
- C. The resin shall produce CIPP, which will comply with the structural and chemical resistance requirements of ASTM F1216.

Table 1 - CIPP Initial Structural Properties

Property	ASTM Test	Minimum Value	
		psi	(MPa)
Flexural Strength	D 790	4,500	(31)
Flexural Modulus	D 790	250,000	(1,724)

2.4 DESIGN CONSIDERATIONS

- A. The CIPP shall be designed per ASTM F1216, Appendix X1.
- B. The CIPP design for the lateral tube shall assume no bonding to the original pipe.
- C. Roughness Coefficient the liner must be smooth and have an average “n” factor of 0.013 or lower.
- D. The CIPP shall be designed for a 50-year useful life or greater.

PART 3 - EXECUTION

3.1 INSTALLATION RECOMMENDATIONS

- A. Access Safety – Prior to entering access areas such as manholes, an excavation pit, performing inspection or cleaning operations, an evaluation of the atmosphere to determine the presence of toxic or flammable vapors or lack of oxygen shall be undertaken in accordance with local, state, or federal safety regulations.
- B. Cleaning and Inspection – As per sections 330130.02 and 330130.17.

- C. Accessing the Lateral – The lateral pipe shall be remotely accessed from the main pipe for purposes of cleaning, pre-inspection, liner insertion and post inspection.
- D. Plugging – The upstream side of the cleanout shall be plugged during insertion and curing of the liner assembly ensuring no flows enter the pipe and no air, steam or odors will enter the building. When required, the main pipe flows will be by-passed. The pumping system shall be sized for normal to peak flow conditions. The upstream manhole shall be monitored at all times and an emergency deflating system will be incorporated so that the plugs may be removed at any time without requiring confined space entry.
- E. Inspection of Pipelines – The interior of the pipeline shall be carefully inspected to determine the location of any condition that shall prevent proper installation, such as roots, and collapsed or crushed pipe sections. These conditions shall be noted. Experienced personnel trained in locating breaks, obstacles, and service connections by closed circuit television shall perform inspection of pipelines.
- F. Line Obstructions – The existing service lateral shall be clear of obstructions that prevent the proper insertion and expansion of the lining system. Changes in pipe size shall be accommodated, if the lateral tube is sized according to the pipe diameter and condition.

Obstructions may include dropped or offset joints of no more than 20% of inside pipe diameter. Where a partial obstruction is caused by the lateral pipe being cocked at the wye connection and protruding into the wye, the protruding portion of the lateral pipe shall be trimmed to provide a clear passage of at least 80% of the inside pipe diameter.

- G. Resin Impregnation – The liner assembly is encapsulated within the translucent bladder (liner/bladder assembly) shall be saturated with the resin system (wet-out) under controlled vacuum conditions. The volume of resin used shall be sufficient to fill all voids in the textile lining material at nominal thickness and diameter. The volume shall be adjusted by adding 5% to 10% excess resin for the change in resin volume due to polymerization and to allow for any migration of resin into the cracks and joints in the original pipe. No dry or unsaturated area in the mainline sheet or lateral tube shall be acceptable upon visual inspection.
- H. Liner Insertion – The lateral tube and inversion bladder will be inserted into the carrying device. The mainline liner and bladder shall be wrapped around a “T” launching device, and held firmly by pacing four (4) hydrophilic O-rings around the main liner. An adhesive sealant 300ml in volume is applied to the main/lateral interface and shall be applied as a two inch (2”) wide band on the main liner. Both the launching and carrying device are pulled into the pipe using a cable winch. The pull is complete when the open port of the “T” launching device is remotely positioned by use of sewer cameras to be aligned with the interface of the service connection and mainline pipe. The lateral tube is completely protected during the pull. The mainline liner is supported on a rigid “T” launcher that is elevated above the pipe invert through the use of a rotating skid system. The liner assembly shall not be contaminated or diluted by exposure to dirt, debris, or water during the pull.

- I. Bladder – The main bladder shall be inflated causing the main sheet to unwrap and expand, embedding the hydrophilic O-rings between the main liner and the main pipe as the main liner is pressed tight against the main pipe. The lateral tube is inverted by the action of the lateral bladder through the center of the main liner as it extends up into the lateral pipe to a distance of three (3) feet. The main/lateral bladder assembly shall extend past all ends of the liner, as no cutting and trimming shall be required.

### 3.2 CIPP PROCESSING

- A. Curing – After the liner has been fully deployed into the lateral pipe, pressure is maintained pressing the liner firmly against the inner pipe wall until the liner is cured at ambient temperatures or by a suitable heat source. The heating equipment shall be capable of delivering a mixture of steam and air throughout the liner bladder assembly to a uniform raise the temperature above the temperature required to cure the resin. The curing of the CIPP must take into account the existing pipe material, the resin system, and ground conditions (temperature, moisture level, and thermal conductivity of the soil). The heat source temperatures shall be monitored and logged during the cure and cool down cycles. The manufacturer’s recommended cure schedule shall be submitted.
- B. CIPP Processing – Curing shall be done without pressure interruption with air or a mixture of air and steam for the proper duration of time per the resin manufacturer’s recommendations. The curing process is complete when the temperature of the CIPP reaches 100 degrees Fahrenheit or less, the processing shall be finished.

### 3.3 FINISH

- A. The finished CIPP – CIPP Shall be a homogenous liner assembly located within a lateral service pipe for a specific length, and extending into the main pipe to renew 16-inches of the main pipe (5” on either side of a 6” lateral or 6” on either side of a 4” connection). The CIPP shall smooth with minimal wrinkling and increase flow rate. The CIPP shall be free of dry spots, lifts, and delaminated portions. The CIPP shall include an engineered taper at each end providing a smooth transition to the host pipe for accommodating video equipment and maintaining proper flow in the mainline. After the work is completed, the installer will provide Owner with video footage documenting the repair and the visual markings identifying the sewer lateral address as completed work. The finished product must provide an airtight/ watertight verifiable non-leaking connection between the main sewer and sewer service lateral.

### 3.4 INSPECTION AND TESTING PRACTICES

- A. Sampling – It is required by the Owner, that Contractor shall prepare a CIPP sample. The sample shall be prepared by securing a flat plate mold using the textile tube material and resin system as used for the rehabilitated pipe.
- B. Pressure – The pressure applied on the plate sample will be equal to the highest pressure exerted on the lateral tube during the inversion process.

- C. Length – The minimum length of the sample must be able to produce at least five specimens for testing in accordance with ASTM D-790-03.
- D. Conditioning – Condition the test specimens at  $73.4 \pm 3.6^{\circ}$  F ( $23 \pm 2^{\circ}$ C) and  $50 \pm 5\%$  relative humidity for not less than 40 hour prior to test in accordance with Practice ASTM D 618, for those tests where conditioning is required.
- E. Short-Term Flexural (Bending) Properties – The initial tangent flexural modulus of elasticity and flexural stress shall be measured for gravity and pressure pipe applications in accordance with Test Method D 790 and shall meet the minimum requirements of Table 1.
- F. CIPP Wall Thickness – The minimum wall thickness at any point shall not be less than 87.5% of the specified design thickness as agreed upon between Owner and Contractor.
- G. Gravity Pipe Leakage Testing – It is required by the Owner that Contractor shall test five percent (5%) of the sealed connections. Contractor shall use an air test method where a test plug is placed adjacent to the upstream and downstream ends of the main sheet CIPP and at the upper most end of the lateral tube. This test should take place after the CIPP has cooled down to ambient temperature. The test pressure shall be 4 PSI for a three-minute) minute test time and during this time the pressure shall not drop below 3.5 PSI.

### 3.5 WARRANTY

- A. All CIPP liners shall be certified by the manufacturer for specified material properties for a particular job. The manufacturer warrants the liner to be free from defects in raw materials for ten (10) years from the date of acceptance. The Contractor guarantees the work to be free from defects caused by faulty workmanship and/or materials for a period of ten (10) years. During the warranty period, any defects which affect the integrity, strength or water tightness of the pipe shall be repaired at the Contractor's expense.
- B. The Contractor shall carry Professional Liability Coverage and provide proof of insurance during the term of the contract.

END OF SECTION 330130.74

## SECTION 333100.03 – SEWER REPAIRS - WILLOWICK

### PART 1 - GENERAL – SEWER REPAIRS

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.
- B. Other Sections Referenced:
  - 1. 330130.19 - Sewer Connection Televising and Rehabilitation
  - 2. 330130.12 - Sewer Line Cleaning
  - 3. 330130.17 - Television Inspection
  - 4. 329200.19 - Seeding and Mulching
- C. Drawings (see Schedules of Work and Detailed Drawings section of these Specifications):
  - 1. Trench & Bedding Details
  - 2. Lateral Replacement Details
  - 3. Pavement and Walk Replacement Details
  - 4. Test Tee Replacement
- D. Other documents which shall be considered part of and included in these specifications:
  - 1. ASTM C 270                      Specification for Mortar for Unit Masonry
  - 2. ASTM D3034                    Specification for Type PSM Polyvinyl Chloride (PVC) Sewer Pipe and Fittings
  - 3. ASTM D3212                    Specifications for Joints for Drain and Sewer Plastic Pipes Using Flexible Elastomeric Seals
  - 4. ODOT Construction and Material Specifications
  - 5. Ohio Manual of Uniform Traffic Control Devices

#### 1.2 DESCRIPTION OF WORK

- A. Under this section, the Contractor shall perform a) complete sanitary and storm test tee/cleanout replacement at or near the right-of-way and b) complete sanitary and storm service lateral replacements including a new mainline tee or approved sewer connection and new test tees and trap at the right-of-way; topped with cast iron covers set at grade.
- B. Sewer repairs are normally performed in established urban areas where the construction work is an inconvenience to the residents, business owners and traveling public. Therefore, the means and methods to be employed by the Contractor and the conduct of the Contractor's employees are important to the City. Any means, methods, or employee used in the execution of work that is too disruptive to the public in the opinion of the City shall be modified by the Contractor to the satisfaction of the City at no additional cost to the City.

### 1.3 QUALITY ASSURANCE

- A. **Manufacturer's Qualifications:** Firms regularly engaged in manufacture of sanitary and/or storm system's products of types, materials, and sizes required, whose products have been in satisfactory use in similar service for not less than five (5) years.
- B. **Installer's Qualifications:** Firms with at least three (3) years of successful installation experience on projects with sanitary and/or storm work similar to that required for project.
- C. **Codes and Standards:**
  - 1. **Plumbing Code Compliance:** Comply with applicable portions of National Standard Plumbing Code pertaining to selection and installation of sanitary and/or storm system's materials and products.
  - 2. **Environmental Compliance:** Comply with applicable portions of local Environmental Agency regulations pertaining to sanitary and/or storm systems.
  - 3. **Utility Compliance:** Comply with applicable portions of protection, installation and/or inspection requirements for each utility encountered during the construction of the point repair.

### 1.4 SUBMITTALS

- A. **Product Data:** Submit manufacturer's technical product data and installation instructions for sanitary and/or storm system materials and products.
- B. **Record Drawings:** At project closeout, submit record drawings of installed sanitary and/or storm sewage piping and products, in accordance with requirements of Division 1.

### 1.5 SUBSURFACE CONDITIONS

- A. The Bidder shall make whatever test holes they deem necessary to determine the subsurface ground conditions, including the presence of water and rock. No extra compensation shall be allowed the Contractor as the result of subsurface conditions encountered with the project. All proposed test holes shall be approved by the City prior to digging.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Pipe, fittings and specials shall be the size and material specified:
  - 1. PVC pipe and fittings shall conform to ASTM D 3034, SDR 26 as shown in the detailed drawings with ASTM D 3212 joints.
  - 2. East Jordan #2960 Frame and Cover or #2790 Frame and Cover with Tri-band coupler for lateral test tees.
  - 3. Flexible rubber couplings with center shear band manufactured by Mission Rubber Company or Fernco Joint Sealer, Inc.
  - 4. Core-N-Seal flexible pipe connectors.



- B. Mortar shall conform to specifications for mortar for Unit Masonry, ASTM C 270 Type S, containing no masonry cement.
  - 1. Mortar shall be composed of one (1) part Portland cement, Type II, to two (2) parts sand by volume.
- C. Brick shall be red shale sewer brick.
- D. Other utility conduits, thrust blocks, and other appurtenances shall be of the size and kind being replaced or as approved by the governing utility company and the City.

## PART 3 - EXECUTION

### 3.1 GENERAL

- A. **Public Notification:** The Contractor shall notify nearby residents and business owners forty-eight (48) hours in advance of beginning each repair. The notification shall briefly describe the work to be performed, state the reason for the work, provide emergency phone numbers, and give a time estimate as to when the work will be completed. The language of the notification shall be approved by the City.
- B. **Utility Notification:** Before any excavation work is started, the Contractor shall call the "Ohio Utilities Protection Service", at 1-800-362-2764, 48 hours in advance of the work. Non-member utilities must be contacted directly. The Contractor shall take all necessary precautions, at no additional expense to the City, to avoid damage to existing underground and overhead utility lines during the entire project. In the event of damage to existing public and/or private utilities, the agency concerned shall be notified immediately and all repair work shall be executed in accordance with the specifications of the respective agency at no additional expense to the City, including any inspection fees or maintenance crews.
- C. **Inspection Scheduling:** The Contractor shall notify the City forty-eight (48) hours in advance of beginning work which requires compaction testing. Work will not begin until testing and/or inspection arrangements have been completed and approved by the City.
- D. **Blasting** will not be permitted.
- E. **Unauthorized Excavations:** All excavations made outside of the lines, grades and replacement limits established by the City, including the excavation, handling, rehandling, backfilling and disposal of such material shall be performed at the Contractor's own expense. This shall include that work caused by cave-ins, slides, swellings or upheavals. All spaces beneath foundations of structures, utilities, pipes or other existing facilities shall be filled with concrete or other acceptable material.
- F. **Noise, Dust and Odor Control:** The Contractor's performance of this Contract shall be conducted so as to eliminate all unnecessary noise, dust and odors. Dust control shall be performed at the Contractor's own expense whenever directed by the City.

- G. The word “rock” wherever used as the name of an excavated material, shall mean boulders and solid masonry larger than one-half cubic yard in volume, of solid ledge rock and masonry which, in the opinion of the City, required for its removal drilling and blasting, edging, sledging or barring, or breaking up with a power-operated hand tool. No soft or disintegrated rock which can be removed with a hand pick or power-operated excavator or shovel; no loose, shaken or previously blasted rock or broken stone in rock fillings or elsewhere; and no rock exterior to the minimum limits of measurement, which may fall into the excavation, will be measured or allowed when extra payment for rock excavation is set forth.

### 3.2 PREPARATORY WORK OUTSIDE PAVED AREAS

- A. The Contractor shall clear the work areas of all trees less than six (6) caliper, shrubs, hedges, plants and flowers as directed by the City.
- B. Shrubs and hedge plants shall be set aside, approximately stored, and replanted after backfilling the excavation. Any shrub or hedge plant that dies prior to expiration of the warranty period shall be replaced with new nursery stock.
- C. All refuse and rubbish shall be cleared from the work area and all tree stumps shall be grubbed out. All cleared material and stumps shall be removed from the work area and disposed of in a manner approved by the City.
- D. No extra compensation will be allowed the Contractor for clearing and grubbing.

### 3.3 PREPARATORY WORK WITHIN PAVEMENT AREAS

- A. The Contractor shall set up traffic control in accordance with Ohio Manual of Uniform Traffic Control Devices to the satisfaction of the City.
- B. The existing pavement shall be neatly saw cut, excavated and disposed of at a location approved by the City.

### 3.4 PROTECTION OF EXISTING UTILITIES

- A. Where existing utilities are indicated as being in the line of the point repair section, the Contractor shall carefully expose them so as to cause no damage to them or interruption of their intended use. Existing pipes or conduits crossing the sewer trench, or otherwise exposed shall be adequately braced and supported to prevent any disruption to the line or grade of the utility.
- B. The Contractor shall keep fire hydrants accessible at all times.
- C. Utility services broken or damaged shall be repaired at once to avoid inconvenience to customers. Storm sewers shall not be interrupted overnight. Temporary arrangements, as approved by the City, may be used until any damaged items can be permanently repaired. All items damaged or destroyed by construction must be subsequently repaired to the satisfaction of the governing utility company.

### 3.5 INSTALLATION

- A. Where the repair is located adjacent to, or within any pavement area, the Contractor shall be required to maintain vertical sides on all trenches using full sheeting and bracing if necessary. In no case will the Contractor be permitted to excavate pipe trenches with sides sloping to the bottom.
- B. All material excavated in trenching and all materials used in construction of the work shall be deposited so as not to endanger the work or create unnecessary annoyance to the public. During the progress of the work, all material piles shall be kept trimmed up and maintained in a neat workmanlike manner. Excavated material in excess of that needed for backfilling shall be disposed of in areas approved by the City.
- C. Construction shall be in accordance with ODOT Item 603, Pipe Culverts, Sewers and Drains and with ODOT Item 604 Manholes, Catch Basins, Inlets, Inspection Wells, Junction Chambers or Monuments with the following exceptions:
  - 1. No slag shall be allowed for any use.
  - 2. Pipe lengths shall not be deflected at the joint to any greater degree than recommended by the manufacturer of the particular joint being used. All pipe deflections shall be performed only with the City's approval.
  - 3. Pipe bedding and trench backfill shall be as per the plan details.
- D. The replacement pipe shall be laid at a uniform grade between the two points of connection with the existing pipe using the equipment and methodology approved for the control of the sewer grade.

### 3.6 LOCATING SERVICE LATERALS

- A. As listed in the specifications and at locations directed by the City, the Contractor shall replace a) pairs of sanitary and storm sewer laterals including mainline tees and test tees/cleanouts or b) pairs of test tees/clean outs (with trap).
- B. The Contractor shall utilize the latest methods of technology to locate the sanitary and storm laterals (laterals, test tees at the right-of-way and mainline tees), including all types of electronic pipe locating and/or televising equipment. If the laterals cannot be located by these methods, then the Contractor shall perform exploratory excavations at their expense.

### 3.7 SALVAGED CASTINGS

- A. The Contractor shall carefully clean all existing castings removed, transport, and store same at a located designated by the City.

### 3.8 CLEANING SITE AND RESTORATION

- A. The Contractor shall restore all disturbed areas to pedestrian and vehicular traffic as follows: Temporary Steel Plates may cover excavation in place of backfill with approval of the City.

1. All excavations in the pavement shall be backfilled at the end of each work day.
  2. A snow fence type of barricade shall be placed around every out of pavement (tree lawn) open excavation at the end of each work day.
  3. Each out of pavement excavation may be left open for a maximum of two (2) working days unless an extensions of time is granted by the City.
- B. Upon completion of the backfill work, the Contractor shall immediately remove and dispose of all surplus materials including dirt and rubbish to the satisfaction of the City.
- C. Unless otherwise called for on the plans, the Contractor shall replace in-kind all damaged or disturbed pavement and sidewalks to a condition equal to or better than the existing before the work was started as a part of performing the sewer repair work.
- D. All restoration of lawns, planting beds, and shrubbery shall be performed in accordance with Sodding, Seeding and Mulching as a part of performing the sewer repair work. The Contractor shall maintain the lawn and correct any settlement that occurs during the correction period.
- E. Upon completion of the foregoing work, all tools and other property belonging to the Contractor shall be removed, and the site shall be left in good condition.

### 3.9 INSPECTION BEFORE ACCEPTANCE

- A. In addition to work being observed by the City during construction, each section of sewer on which a point repair is made shall be inspected in accordance with television inspection before final acceptance by the City. The sewer repair shall be true to both line and grade, free from cracks, broken bells, and protruding joint materials and shall show no leaks. The hydraulics of the sewer shall be in no ways be impaired. There shall be no projections of connecting pipe into the sewer. Any deposits of sand, dirt, mortar, or other materials shall be removed from the pipe in accordance with Sewer Line Cleaning at no additional cost to the City.
- B. If, as the result of any inspection, before final acceptance of the work or within the correction period, it is found that any section of any sewer repaired or replaced has unduly settled, that joints have opened up or when the jointing material has come loose and projects into the sewer, or if pipes or bells are found cracked, broken or misshaped beyond accepted standards, or if any other defects are found in the sewers or in any of their appurtenances which might impair the satisfactory performance of the sewer or which show non-conformance with the drawings of Specifications, the Contractor shall cause such defective or inferior work to be promptly removed and replaced or satisfactorily repaired by proper material and workmanship without extra compensation for the labor, equipment and materials required.
- C. Should the City require that any work be uncovered because of suspected failure or non-conformance or for inspection or other cause, and if such work is subsequently found satisfactory, the cost involved for such work will be paid for at the unit price bid for the respective items of work involved.

END OF SECTION 333100.03