



Meeting Summary

To: Attendees and Plan Holders

Subject: Adams Lake State Park and Welcome Center
Pump Station and Force Main

Date: June 1, 2022

A Pre-bid Conference was held on May 24, 2022. An attendance list was handed out and signed by all. A copy of the sign-in sheet is attached. Highlights of the meeting are as follows:

- Kent Bryan reviewed the project with those in attendance. It was noted that the project funding was 100% local funds of the Adams County. It did not include any State or Federal grant funding. Therefore, the wages rates for this project will be State of Ohio Prevailing Wage Rates.
- Installation of a new packaged grinder lift station and force main to serve the Adams Lake State Park Welcome Center.
- The main electrical power will be from AEP and any charges from AEP will be paid directly by Adams County. The Bidder is to include electrical cost to install and wire the main control panel that is to be provided by the pump station supplier.
- It was clarified that there is only one 6-inch HDPE direction drill under State Road 41. The 6-inch pipe will act as the casing pipe and the 2-inch line is to be installed inside the casing.
- It was noted that given the short length of the piping and shallow installation, no soil borings were performed for this project. It is anticipated that rock will be encountered for most of the installation of the 2-inch force main on the west side of State Road 41. Rock may be encountered on the east side of SR 41. The contractor is responsible to investigate the site to determine the depth of rock. The contractor may excavate an inspection hole on the west side of SR 41, after notifying Holly Johnson of Adams County who will notify the ODNR.

KAB: nld