



April 11, 2022

ADDENDUM NO. 01

To the Plans and Specifications for:

Project No. 22005
North Royalton
Baseball Field Lighting Upgrade Phase 3

TO ALL BIDDERS:

This addendum supplements and amends the original drawings and specifications, and shall be taken into account in the preparing proposals, and shall become part of the contract documents by reference. Receipt of this addendum must be acknowledged on the bid form.

Addendum consists of the following:

Questions:

Item Q1: For the removal of the wire and conduit to the nearest junction box does that mean to remove it back to the nearest junction box on the pole or in ground junction box.

The wire will be removed back to the nearest junction box on the pole.

If you have any questions regarding the above, please do not hesitate to call.

Very truly yours,

Scheeser Buckley Mayfield LLC

A handwritten signature in black ink, appearing to read 'J E U', is written over a light blue horizontal line.

James E. Eckman, PE, LEED AP, LC, CBCP
President

M:\2022\22005\Design\Addendum\2022-04-11 North Royalton Ball Field Lighting Upgrade Phase 3 Addendum 01.docx