

To: All Plan Holders of Record

From: CT Consultants, Inc.  
For the Owner

**Re: *Addendum No. 1***  
***Second Floor Interior Staff Improvements***  
***Mentor Public Library***

Date: November 18, 2022

This Addendum forms a part of the contract documents and modifies the original bidding documents dated November 2022 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

## **PLANS**

On plan sheet E1.2:

1. Second Floor Lighting Plan: Existing Break Room Kitchenette exhaust fan shall be supplied with speed control to be mounted at island switch locations.
2. Add occupancy sensor / switch in Wellness Room 211 and in Break Room 213.
3. Second Floor Power and Communication Plan: New receptacles in Single User ADA Toilet 205, 206 and 209 shall be GFCI protected.
4. Existing Panel "CA": Circuit Breakers #17, #21, #23, #25, #27 and #28/30 are existing circuit breakers to remain. See plan for circuit location / relocation.

On plan, sheet A-01:

1. In Child's Toilet 203 and 204. In lieu of new baby changing counter tops. Provide and install Koala Baby changing stations. Model as indicated in "Specification" section below.

## **SPECIFICATIONS**

1. 102800: Toilet Accessories: ADD: Paper Towel Dispenser and Waste Receptacle Model B39747: Recessed cabinet. 18-8, Type 304 stainless steel. Automatic Roll Towel Dispenser. Battery Operated. Quantity-(4). Each Single User Toilet Room and the Wellness Room.
2. 102800: Koala Baby changing station: Model No. KB200. Quantity-(2) – in each Child Toilet.

ADT:mep

Enclosures

H:\2022\220197\SPEC\Addenda\Addendum 01\Addendum 01.Doc