

To: All Plan Holders of Record

From: CT Consultants, Inc.  
For the Owner

**Re: *Addendum No. 1***  
***2023 Asphalt Pavement Program***  
***Village of Hartville***

Date: February 21, 2023

This Addendum forms a part of the contract documents and modifies the original bidding documents dated February 2023 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

### **QUESTIONS AND ANSWERS**

Q1. Is it acceptable to substitute precast concrete risers instead of using brick and mortar. This would help minimize the salt breaking down the mortar joints in the top 12” of the basins or manholes.

**A1. Precast Concrete Risers are acceptable.**

Q2. Are we to include the cost of the paving fabric into the cost of asphalt? Or is the fabric not to be used.

**A1. Fabric will not be used on this project. Exhibit 1A to 5A were revised accordingly.**


### **DRAWINGS AND STANDARD DETAILS**

In Section 9, **Replace** drawing sheets Exhibit 1 to 5 with the enclosed sheets Exhibit 1A to 5A.


SA/AK:mep

Enclosures

H:\2023\23010501\SPEC\Addenda\Addendum 01.Doc




PROJECT LENGTH:  
 BASE BID: ABOUT 660 FT  
 ERIE AVE LENGTH: ABOUT 145 FT  
 MILLER AVE LENGTH: ABOUT 145 FT  
 GLENBERRY AVE NE LENGTH: ABOUT 275 FT  
 GRANDTRUNK AVE SW LENGTH: ABOUT 1230 FT  
 ALTERNATE BID:  
 LAKE AVE LENGTH: ABOUT 2200 FT




REVISION NO. 1

- REVISED TO REMOVE PAVEMENT FABRIC.
- REVISED TO REMOVE NON TRACKING TACK COAT, 0.075 GAL/SY




**EXHIBIT 1A**  
**2023 PAVING PROGRAM**  
**VILLAGE OF HARTVILLE, OHIO**

SCALE:	AS SHOWN
DATE:	FEB-2023
DESIGNED BY:	ANK
DRAWN BY:	ANK
CHECKED BY:	SA






PROJECT LENGTH:  
 BASE BID: ABOUT 660 FT  
 ERIE AVE LENGTH: ABOUT 145 FT  
 MILLER AVE LENGTH: ABOUT 145 FT  
 GLENBERRY AVE NE LENGTH: ABOUT 275 FT  
 GRANDTRUNK AVE SW LENGTH: ABOUT 1230 FT  
 ALTERNATE BID:  
 LAKE AVE LENGTH: ABOUT 2200 FT







REVISION NO. 1  
 • REVISED TO REMOVE PAVEMENT FABRIC.  
 • REVISED TO REMOVE NON TRACKING TACK COAT, 0.075 GAL/SY



SCALE:	AS SHOWN
DATE:	FEB-2023
DESIGNED BY:	ANK
DRAWN BY:	ANK
CHECKED BY:	SA

## EXHIBIT 2A 2023 PAVING PROGRAM VILLAGE OF HARTVILLE, OHIO







SCALE:	AS SHOWN
DATE:	FEB-2023
DESIGNED BY:	ANK
DRAWN BY:	ANK
CHECKED BY:	SA

## EXHIBIT 3A 2023 PAVING PROGRAM VILLAGE OF HARTVILLE, OHIO



PROJECT LENGTH:  
 BASE BID: ABOUT 660 FT  
 ERIE AVE LENGTH: ABOUT 145 FT  
 MILLER AVE LENGTH: ABOUT 145 FT  
 GLENBERRY AVE NE LENGTH: ABOUT 275 FT  
 GRANDTRUNK AVE SW LENGTH: ABOUT 1230 FT  
 ALTERNATE BID:  
 LAKE AVE LENGTH: ABOUT 2200 FT




REVISION NO. **1**

- REVISED TO REMOVE PAVEMENT FABRIC.
- REVISED TO REMOVE NON TRACKING TACK COAT, 0.075 GAL/SY

**PROJECT LENGTH:**

BASE BID: ABOUT 660 FT  
 ERIE AVE LENGTH: ABOUT 1400 FT  
 WAGNER CT LENGTH: ABOUT 345 FT  
 MILLER AVE LENGTH: ABOUT 1000 FT  
 GRANDTRUNK AVE SW LENGTH: ABOUT 1230 FT

ALTERNATE BID: ABOUT 2200 FT  
 LAKE AVE LENGTH:



BASE BID

ALTERNATE BID-LAKE AVE



REVISION NO. **1**

- REVISED TO REMOVE PAVEMENT FABRIC.
- REVISED TO REMOVE NON TRACKING TACK COAT, 0.075 GAL/SY




**EXHIBIT 4A**  
**2023 PAVING PROGRAM**  
**VILLAGE OF HARTVILLE, OHIO**

SCALE:	AS SHOWN
DATE:	FEB-2023
DESIGNED BY:	ANK
DRAWN BY:	ANK
CHECKED BY:	SA



**PROJECT LENGTH:**

BASE BID: ABOUT 660 FT  
 WAGNER CT LENGTH: ABOUT 1400 FT  
 MILLER AVE LENGTH: ABOUT 345 FT  
 GLENBERRY AVE NE LENGTH: ABOUT 275 FT  
 GRANDTRUNK AVE SW LENGTH: ABOUT 1230 FT  
 ALTERNATE BID: ABOUT 2200 FT  
 LAKE AVE LENGTH: ABOUT 2200 FT



- ① PAVEMENT PLANING (4" AVERAGE)
- ② 1-3/4" ASPHALT CONCRETE SURFACE COURSE PER PG 64-22, AS PER PLAN (448)
- ③ 2-1/4" ASPHALT CONCRETE INTERMEDIATE COURSE TYPE 2, (448)
- ④ NON-TRACKING TACK COAT FOR INTERMEDIATE COURSE, 0.04 GAL/SY.




REVISION NO. **1**

- REVISED TO REMOVE PAVEMENT FABRIC.
- REVISED TO REMOVE NON TRACKING TACK COAT, 0.075 GAL/SY



SCALE:	AS SHOWN
DATE:	FEB-2023
DESIGNED BY:	ANK
DRAWN BY:	ANK
CHECKED BY:	SA



**EXHIBIT 5A**  
**2023 PAVING PROGRAM**  
**VILLAGE OF HARTVILLE, OHIO**

