



To: All Plan Holders of Record

From: CT Consultants, Inc.

Re: *Addendum No. 1*
Midwest Materials Sanitary Sewer Improvements

Date: May 14, 2018

This Addendum forms a part of the contract documents and modifies the bidding documents dated September, 2018. Acknowledge receipt of this addendum in the space provided on the "proposal forms." Failure to do so may subject the bidder to disqualification.

PLANS

1. Sheet 20 of 22, make the following changes to the elevations labels for Pump Station No. 1:
Bottom of wet well at elevation 682.00; all pumps off at elevation 683.08; 1st pump on at elevation 683.42 and 2nd pump on/alarm at elevation 684.08.

QUESTIONS FROM BIDDERS

No questions have been received to date.

H:\2017\170415\SPEC\Addendum 01.Docx